



- ### DEMOLITION KEYED NOTES:
- 1 REMOVE STEAM PIPING FROM BOILER CONNECTION TO VALVE SHOWN. VALVE TO REMAIN. VALVE TO BE LOCKED IN THE CLOSED POSITION.
 - 2 REMOVE (3) FUEL OIL LINES TO LOCATION SHOWN. CAP FOR CONNECTION OF NEW PIPING.
 - 3 REMOVE BOILER STEAM SUPPLY PIPING.
 - 4 REMOVE BOILER RELIEF PIPING AND SEAL ROOF WEATHER TIGHT.
 - 5 REMOVE BOILER FEED WATER PIPING. CAP FOR CONNECTION OF NEW PIPING.
 - 6 REMOVE NATURAL GAS PIPING. CLOSE VALVE UPSTREAM OF PRESSURE REGULATOR.
 - 7 REMOVE STEAM PIPING. CAP AT MAIN.
 - 8 REMOVE WINDOW SYSTEM FOR BOILER INSTALLATION.
 - 9 REMOVE AND RELOCATE EXISTING CONDUIT.

- GENERAL DEMOLITION NOTES:
1. ALL ITEMS SHOWN ARE EXISTING.
 2. ALL ITEMS SHOWN HATCHED SHALL BE REMOVED.
 3. CAP ALL PIPE MAINS WHERE BRANCHES ARE TO BE REMOVED.
 4. NOT ALL EXISTING MECHANICAL EQUIPMENT, DUCTWORK, AND PIPING SHOWN.
 5. ALL SHUT DOWNS AND TIE-INS THAT AFFECT OR MAY AFFECT THE 24/7 OPERATION OF STEAM GENERATION FROM BOILERS 1 AND 2, INCLUDING NATURAL GAS, PROPANE, FEED WATER, CHEMICAL TREATMENT, STEAM DISTRIBUTION, ELECTRICAL ETC. SHALL BE FULLY COORDINATED WITH THE VA PROJECT MANAGER A MINIMUM OF 12 HOURS PRIOR TO THE EVENT.

		CONSULTANTS:		ARCHITECT/ENGINEERS: <div>LEO A DALY PLANNING ARCHITECTURE ENGINEERING INTERIORS EST. 1915</div> <div>8600 Indian Hills Drive Omaha, NE 68114-4039 USA Tel 402-391-8111 Fax 402-391-8564</div>	Architect Project No. 003-10099-009	Drawing Title MECHANICAL ROOM DEMOLITION PLAN	Project Title BOILER REPLACEMENT	Project Number 636-13-102	Office of Construction and Facilities Management
						Building Number 2			
					Approved Project Director	Location OMAHA, NE	Drawing Number MD103		
					Name	Date JUNE 28, 2013	Checked KRC	Drawn TRF	
Revisions:	Date								
									Department of Veterans Affairs