


NOTE:
 COOLING TOWER CT-4 IS PART OF
 A DEDUCTIVE ALTERNATE. IF THE
 ALTERNATE IS ACCEPTED DELETE
 CT-4 AND RELATED PIPING, BLIND
 FLANGE THE 10" CWR AND 12"
 CWS DISCHARGE ADJACENT TO
 COOLING TOWER CT-3 BRANCH
 PIPING.

Bid Documents

GENERAL REVISION	11/8/13
Revisions:	Date

CONSULTANTS:

AINSWORTH ASSOCIATES
 MECHANICAL ENGINEERS
 3741 BUSINESS DR. SACRAMENTO, CA 95820
 TEL: 916-737-6014 FAX: 916-737-6015
 1420 HOLCOMB AVE., SUITE 201 RENO, NV 89502
 TEL: 775-329-9100 FAX: 775-329-9105
 www.ainw.com



ARCHITECT/ENGINEERS:

H+K ARCHITECTS
 5485 Reno Corporate Dr., Ste. 100
 Reno, Nevada 89511-2262
 P 775-332-6640
 F 775-332-6642
 hkarchitects.com



Drawings Title
CATWALK LEVEL MECHANICAL PLAN

Approved: Project Director

Project Title
COOLING TOWER REPLACEMENT

Project Number
 654-13-370

Building Number
 8

Location
 975 Kirman Avenue, Reno, NV. 89502

Date
 October 24, 2013

Checked
 JSH

Drawn
 ER

Drawing Number
MP003

Office of
 Construction
 and Facilities
 Management

Department of
 Veterans Affairs