




**B1** PARTIAL PALN BLDG #5 - G08 / G09 DEMO  
1/4" = 1'-0"




**C2** PARTIAL PLAN BLDG #5 - G08 / G09 NEW CONSTRUCTION  
1/4" = 1'-0"




**C1** PARTIAL PLAN BLDG #5 - G11C NEW CONSTRUCTION  
1/4" = 1'-0"




**D1** PARTIAL PLAN BLDG #5 - G25B NEW CONSTRUCTION  
1/4" = 1'-0"



**E3** BLDG #5 - G08 / G09 LIGHTING AND POWER  
1/8" = 1'-0"



**E2** BLDG #5 - G25B LIGHTING AND POWER  
1/8" = 1'-0"



**E1** BLDG #5 - G11C LIGHTING AND POWER  
1/8" = 1'-0"


- GENERAL NOTES:**
- EQUIPMENT IN ELECTRICAL ROOMS SHALL BE ARRANGED TO MAXIMIZE SPACE FOR FUTURE EQUIPMENT. THE LAYOUTS OF THE ROOMS INDICATED ON THESE PLANS ARE BASED UPON A SPECIFIC MANUFACTURER. EQUIPMENT BY OTHER MANUFACTURERS WILL VARY. CONTRACTOR SHALL SUBMIT COORDINATION DRAWINGS AS SPECIFIED IN 260511 FOR ALL ELECTRICAL SPACES, WHICH SHALL INDICATE ALL PROPOSED EQUIPMENT INSTALLED IN THE ELECTRICAL ROOM UNDER ALL DIVISIONS. ANY ITEMS IN THE ELECTRICAL ROOMS THAT ARE NOT INSTALLED AS INDICATED ON THE APPROVED COORDINATION DRAWINGS MAY BE REQUIRED TO BE RELOCATED AT THE CONTRACTOR'S EXPENSE.
- KEYED NOTES (THIS SHEET ONLY):**
- CIRCUIT TO AN AVAILABLE 20A/1P BREAKER.
  - POWER CONNECTION TO FAN COIL UNIT. SEE MECHANICAL PLANS.
  - CIRCUIT TO AN AVAILABLE 15A/2P BREAKER.



| Revisions | Date |
|-----------|------|
|           |      |
|           |      |
|           |      |
|           |      |



Tennessee Valley Healthcare System



|  |                           |
|--|---------------------------|
| Project Title: UPGRADE ELECTRICAL DISTRIBUTION PHASE 3           | Date: OCTOBER 31, 2012    |
| Drawing Title: ELECTRICAL ENLARGED PLANS BUILDING 5 GROUND FLOOR | Project No.: 626A4-11-202 |
| Approved By: [Signature]   | Drawing No.: 5-E5.200     |
| Building Number: 5   | Dwg. 79 of 97             |

Department of Veterans Affairs