



United American Builders, Inc.

REQUEST FOR INFORMATION R.F.I.

Job Name: Expand Eye Clinic - Baltimore VA Medical Center
Job Address: 10 North Greene Street Baltimore, MD 21201
From: Warren Tasca
To: Sophie Spencer

R.F.I Date: 19-Nov-13

R.F.I No.: 01

Via: Email

Division No.	09 - Finishes
Spec's Section	09 29 00
Drawings Page/s No.	A101

Reference made to: A101 - Wall Type S6 - Not Shown

Question

On drawing A101 in the "Imaging/Us" room is shows approximately 3 linear feet of Wall Type S6. Nowhere on the drawing does it show a Wall Type S6.

Please provide further detail/clarification.

Answer

The referenced wall is listed incorrectly. — it should be wall type "S2" instead of "S6"

— Mike Trupu

11/25/13