

DATE: DECEMBER, 4 2013
FROM: PFB ARCHITECTS
SUBJECT: ADDENDUM No. I - SUMMARY OF ADDENDUM DOCUMENTS
PROJECT: **RELOCATE JOLIET CBOC PHASE II - BID PACKAGE C**
TO: **OWNER, CONTRACTORS**

ALL OF THE BID DRAWINGS ARE DATED 7.25.2013
ADDENDUM I DATED 12.4.2013

DRAWINGS INCLUDED:

Architectural:

GI006

SPECIFICATION SECTIONS INCLUDED:

Sections:

010000, 238200, 262816, 262923, 312000

Description:

Sheet GI006 – Replaces previously issued sheet GI006 – Added bidder note and revised deductive alternates

Sheet GI007 – Sheet GI007 is deleted from the bid set - First Floor Construction Plan - Area B5 - Additive Alternate #1 is not to be included in bids. Contractor is to remove all references to Additive Alternate #1 throughout their bid. Contractor is not to bid any portion of Additive Alternate #1. **Narrative Only, no drawings issued**

Sheet GI008 – Sheet GI008 is deleted from the bid set - First Floor Construction Plan - Area B5 - Additive Alternate #2 is not to be included in bids. Contractor is to remove all references to Additive Alternate #2 throughout their bid. Contractor is not to bid any portion of Additive Alternate #2. **Narrative Only, no drawings issued**

Sheet PL110B – Add one hose bibb, HB-1 and one BFP-1 in mechanical room B026 near column lines D/9. The hose bibb shall connect to the existing 1" CW line at that location with a ¾" line and shall be located 30" AFF. Locate BFP-1 on the wall behind HB-1. The hose bibb shall be attached to the west wall of the mechanical room. **Narrative Only, no drawing issued**

Sheet PL110A – Add one hose bibb, HB-1 and one BFP-1 in mechanical room B026 near column lines B1/9. The hose bibb shall connect to the existing 1" CW line at that location with a ¾" line and shall be located 30" AFF. Locate BFP-1 on the wall behind HB-1. The hose bibb shall be attached to the west wall of the mechanical room. **Narrative Only, no drawing issued**

Sheet PL500 - Add hose bibb, HB-1, specified as follows the plumbing materials list:

HB-1, HOSE BIBB - INDOOR WALL HYDRANT, BRASS CONSTRUCTION, STANDARD FINISH, 3/4" MALE HOSE THREAD, METAL WHEEL HANDLE
ACCEPTABLE MANUFACTURERS: WOODFORD 24 OR EQUAL
Narrative Only, no drawing issued

Sheet T000 - **REMOVE** "NO EQUAL" reference from Information Outlet Schedule General Note 1. Part numbers listed represent basis of design as associated with existing warranted technology systems. Refer to individual specification sections for warranty requirements of existing systems. **Narrative Only, no drawing issued**

Sheet T600 - **REMOVE** "NO EQUAL" reference from all material list items. Part numbers listed represent basis of design as associated with existing warranted technology systems. Refer to individual specification sections for warranty requirements of existing systems. **Narrative Only, no drawing issued.**

Specification 000110 – Specification section 096519 & 251010 have been removed from the table of contents. Specification section 312000 has been added to the table of contents. **Narrative Only, no specification issued.**

Specification 010000 – Note to Bidders added to Section 1.2 Statement of Bids, Section 1.6.F modified to include vibration and noise restrictions. Replaces previously issued section 010000.

Specification 238200 – Specification section originally referenced in the Table of Contents is now provided as part of the Contract Documents.

Specification 262816 – Specification section originally referenced in the Table of Contents is now provided as part of the Contract Documents.

Specification 262923 – Specification section originally referenced in the Table of Contents is now provided as part of the Contract Documents.

Specification 312000 – Specification section added.

– END OF ADDENDUM –