



Replace ductwork highlighted in yellow

2" STEAM CONDENSATE DOWN THROUGH FINISHED FLOOR. ROUTE NEW CONDENSATE TO EXISTING PIPE TUNNEL BELOW. CONNECT NEW CONDENSATE TO EXISTING MIN. 2" CONDENSATE MAIN IN SUB-BASEMENT UTILITY TUNNEL.

ROUTE PIPING TO BUILDING BELOW NEW DUCTWORK AND AHU. PITCH ALL PIPING TOWARDS BUILDING.

PROVIDE NEW DUCT PENETRATIONS THRU EXIST MASONRY WALL. PROVIDE LINTELS AS REQUIRED. (TYP)

CONNECT TO EXIST 2 1/2" LPS HEADER

CONNECT TO EXIST 1" LPS HEADER

PROVIDE 24" DIA. BLINDWELL CONNECTION

24" DIA. BLINDWELL CONNECTION

24" DIA. BLINDWELL CONNECTION

24" DIA. BLINDWELL CONNECTION

24" DIA. BLINDWELL CONNECTION

24" DIA. BLINDWELL CONNECTION

24" DIA. BLINDWELL CONNECTION