




three inches = one foot
 one and one half inches = one foot
 one inch = one foot
 three quarters inch = one foot
 one half inch = one foot
 three eighths inch = one foot
 one eighth inch = one foot
 one quarter inch = one foot
 one eighth inch = one foot




SECTION "A-A"
SCALE: NONE




SECTION "B-B"
SCALE: NONE




SECTION "C-C"
SCALE: NONE



SECTION "D-D"
SCALE: NONE



LIGHT POLE FOUNDATION DETAIL
SCALE: NONE




LIGHT POLE FOUNDATION DETAIL
SCALE: NONE

- KEY NOTES:**
- POLE MTD. LUMINAIRE. REFER TO LUMINAIRE SCHEDULE AND SITE PLAN FOR DETAILS.
 - REFER TO LUMINAIRE SCHEDULE AND SITE PLAN FOR MOUNTING HEIGHT ASSOCIATED WITH SPECIFIC LUMINAIRE TYPE.
 - STEEL POLE WITH BASE PLATE AND BASE COVER (NOT SHOWN).
 - PROVIDE IN-LINE FUSE IN PHASE CONDUCTOR.
 - POLE BASE PLATE (BASE COVER NOT SHOWN).
 - 1" DIAMETER X 36" LONG ANCHOR BOLT FURNISHED WITH POLE ASSEMBLY. (TYPICAL OF 4).
 - REINFORCED CONCRETE BASE, SONOTUBE FORMED, 3000 PSI MINIMUM COMPRESSION STRENGTH.
 - #4 REBAR VERTICAL CORNERS WITH #3 REBAR HORIZONTAL TIES AT 12" OC.
 - 3/4" X 10'-0" COPPER-CLAD GROUND ROD.
 - EXOTHERMIC CADWELD CONNECTION OF GROUNDING CONDUCTOR TO DRIVEN GROUND ROD.
 - 1" PVC WITH ONE (1) #8 AWG GROUNDING CONDUCTOR.
 - CHAMFER CORNER.
 - GROUT.
 - BOND GROUNDING CONDUCTOR TO INSIDE OF POLE NEAR HAND-HOLE.
 - 3"x5" REINFORCED HAND-HOLE WITH GASKETED COVER AND TAMPER RESISTANT SCREWS.
 - CONCRETE HEIGHT AFG AS STATED IN LUMINAIRE SCHEDULE.

- KEY NOTES:**
- POLE MTD. LUMINAIRE. REFER TO LUMINAIRE SCHEDULE AND SITE PLAN FOR DETAILS.
 - REFER TO LUMINAIRE SCHEDULE AND SITE PLAN FOR MOUNTING HEIGHT ASSOCIATED WITH SPECIFIC LUMINAIRE TYPE.
 - STEEL POLE WITH BASE PLATE AND BASE COVER (NOT SHOWN).
 - PROVIDE IN-LINE FUSE IN PHASE CONDUCTOR.
 - POLE BASE PLATE (BASE COVER NOT SHOWN).
 - 1" DIAMETER X 36" LONG ANCHOR BOLT FURNISHED WITH POLE ASSEMBLY. (TYPICAL OF 4).
 - CONCRETE DECK.
 - #4 REBAR VERTICAL CORNERS WITH #3 REBAR HORIZONTAL TIES AT 12" OC.
 - STRUCTURAL COLUMN.
 - PVC BRANCH CIRCUIT CONDUIT, 1" MINIMUM.
 - #8 AWG GROUNDING CONDUCTOR TO REINFORCING STEEL.
 - CHAMFER CORNER.
 - GROUT.
 - BOND GROUNDING CONDUCTOR TO INSIDE OF POLE NEAR HAND-HOLE.
 - 3"x5" REINFORCED HAND-HOLE WITH GASKETED COVER AND TAMPER RESISTANT SCREWS.


- GENERAL NOTES:**
- POLE BASE DEPTH, DIAMETER, REBAR SIZES AND QUANTITIES, AND CONCRETE PSI ARE SHOWN FOR ESTIMATING PURPOSES ONLY. PROVIDE FOR, AND SUBMIT TO THE ENGINEER, A POLE BASE INSTALLATION DETAIL THAT HAS BEEN PREPARED AND PROFESSIONALLY SEALED BY A STRUCTURAL ENGINEER.
 - THE SUBMITTED INSTALLATION DETAIL SHALL SPECIFY EXACT POLE BASE DIMENSIONS, MATERIALS, ETC. FOR EACH DIFFERENT POLE-MOUNTED LUMINAIRE TYPE AS INDICATED ON THE LUMINAIRE SCHEDULE AND ON THE PLANS. ALL LUMINAIRE POLES AND POLE BASES SHALL BE DESIGNED AND PROVIDED AS REQUIRED FOR PROPER STRUCTURAL SUPPORT AGAINST ALL STATIC AND DYNAMIC LOADS INCLUDING WIND LOADS UP TO 100 MPH AND SHALL BE SPECIFIC USING THE ACTUAL EPA VALUES FOR THE POLES AND LUMINAIRES BEING PROVIDED FOR THIS PROJECT.

- GENERAL NOTES:**
- POLE BASE DEPTH, DIAMETER, REBAR SIZES AND QUANTITIES, AND CONCRETE PSI ARE SHOWN FOR ESTIMATING PURPOSES ONLY. PROVIDE FOR, AND SUBMIT TO THE ENGINEER, A POLE BASE INSTALLATION DETAIL THAT HAS BEEN PREPARED AND PROFESSIONALLY SEALED BY A STRUCTURAL ENGINEER.
 - THE SUBMITTED INSTALLATION DETAIL SHALL SPECIFY EXACT POLE BASE DIMENSIONS, MATERIALS, ETC. FOR EACH DIFFERENT POLE-MOUNTED LUMINAIRE TYPE AS INDICATED ON THE LUMINAIRE SCHEDULE AND ON THE PLANS. ALL LUMINAIRE POLES AND POLE BASES SHALL BE DESIGNED AND PROVIDED AS REQUIRED FOR PROPER STRUCTURAL SUPPORT AGAINST ALL STATIC AND DYNAMIC LOADS INCLUDING WIND LOADS UP TO 100 MPH AND SHALL BE SPECIFIC USING THE ACTUAL EPA VALUES FOR THE POLES AND LUMINAIRES BEING PROVIDED FOR THIS PROJECT.




RACK POWER POLE DETAIL
SCALE: NONE

- GENERAL NOTES:**
- EC TO PROVIDE (1) NEMA 5-20R DOUBLE DUPLEX RECEPTACLE AND (1) NEMA L6-30R RECEPTACLE EACH IN 4" x 4" BACKBOXES MOUNTED VERTICALLY ON FLOOR MOUNTED UNISTRUT SUPPORT.
 - BOTTOM RECEPTACLE TO BE MOUNTED AT 18".
 - MOUNT SUCH THAT FRONT FACE OF RECEPTACLES ARE 9" FROM BACK CORNER POST OF RACK, TYPICAL.
- KEY NOTES:**
- DEDICATED EMERGENCY POWER CIRCUITS - 120V NEMA 5-20R DOUBLE DUPLEX.
 - DEDICATED EMERGENCY POWER CIRCUIT - 208V NEMA L6-30R.



DUCT BANK DETAILS
SCALE: NONE

- DUCT BANK NOTES:**
- CONCRETE SHALL BE 2000 P.S.I. @ 28 DAYS, OR AS SPECIFIED.
 - PROVIDE REINFORCING RODS ON TOP AND BOTTOM OF DUCTS WHEN CROSSING OR PLACED IN ROADWAYS OR DRIVING AREAS.
 - MINIMUM COVER TO TOP OF ENVELOPE SHALL BE 24" (610mm).
 - PROVIDE MINIMUM 6" (152mm) SPACE BETWEEN POWER AND TELECOMMUNICATION DUCTS. INCREASE SIZE AS REQUIRED.
 - INNERDUCT QUANTITY AND SIZE AS INDICATED ON PLANS.



GROUNDING BAR DETAIL
SCALE: NONE

- GENERAL NOTES:**
- ALL HARDWARE SHOWN SHALL BE STAINLESS STEEL.
 - PROVIDE 1 MOUNTING POINT PER 12" OF BAR LENGTH.
 - HOLES MAY BE ADDED IF REQUIRED.

No.	Description	Date
DD#1		07/09/2012
DD#2		08/13/2012
CD#1		09/24/2012
CD#2		11/02/2012
	FINAL SUBMITTAL	05/07/2013
Revisions:		Date

CONSULTANTS	

ARCHITECT/ ENGINEERS	
Westlake Reed Leskosky	
The Huntington Building 925 Euclid Avenue, Suite 1900 Cleveland, Ohio 44115-1407 216.522.1350	

Drawing Title	ELECTRICAL DETAILS
Approved: Project Director	

Project Title	VA Erie Parking Structure
Location	Erie, PA
Date	9/24/2013
Checked	MSB
Drawn	SRH
Project Number	11159.00
Building Number	
Drawing Number	E-502

Office of Construction and Facilities Management
 Department of Veterans Affairs

FINAL SUBMITTAL