

DEDUCT ALT #10: STAIR TO BE DELETED, SEE ARCH. DELETE ASSOCIATED EQUIPMENT AND APPURTENANCES.

1 MECHANICAL SECOND FLOOR PLAN
3/32" = 1'-0"

GENERAL NOTES

1. SEE M100 FOR MECHANICAL SYMBOLS & ABBREVIATIONS.
2. SEE M501 FOR MECHAINCAL DETAILS.
3. SEE M601 & M602 FOR MECHANICAL CONTROL DIAGRAMS.
4. SEE M701 FOR MECHANICAL SCHEDULES.
5. PROVIDE CONNECTION OF MECHANICAL EQUIPMENT THROUGHOUT GARAGE TO BUILDING CONTROL PANEL IN 106 - STORAGE.

SHEET NOTES

1. SEE ARCH FOR LOUVERS (MIN 1.1 SF OF FREE AREA EACH). (DEDUCT ALT #10)
2. PROVIDE CONCRETE EQUIPMENT CURB FOR CU-1. SEE DETAIL 8/M-501.
3. PROVIDE REFRIGERANT PIPING AND RELATED APPURTENANCES FROM CU-1 TO ACU-1, ACU-2 & ACU-3. REFRIGERANT SYSTEM TO BE DESIGNED AND SIZED BY EQUIPMENT MANUFACTURER. SYSTEM ROUTING SHOULD BE SUBMITTED TO ARCHITECT FOR APPROVAL PRIOR TO INSTALLATION.

FINAL SUBMISSION

Scale: 3/32" = 1'-0"

No.	Description	Date
	FINAL SUBMISSION	9/24/2013
Revisions:		Date

CONSULTANTS

ARCHITECT/ ENGINEERS

Westlake Reed Leskosky

The Huntington Building
925 Euclid Avenue, Suite 1900
Cleveland, Ohio
44115-1407
216.522.1350

Drawing Title: MECHANICAL LEVEL 2 PLAN

Approved: Project Director

Project Title: VA Erie Parking Structure

Location: Erie, PA

Date: 9/24/2013 | Checked: SCS | Drawn: CJW

Project Number: 11159.00

Building Number:

Drawing Number: **M102**

Office of Construction and Facilities Management

Department of Veterans Affairs