

KEYED CONSTRUCTION NOTES

1. DISCONNECT EXISTING 15 AMP 3 POLE CIRCUIT BREAKER FEEDING EXISTING EXHAUST FAN 2 IN PANEL 2AH1 . REUSE EXISTING 15 AMP 3 POLE CIRCUIT BREAKER TO FEED EXHAUST FAN 2A. PROVIDE AND INSTALL 3 #12 CONDUCTORS AND #12 GROUND IN 3/4" CONDUIT TO DISCONNECT SWITCH. PROVIDE NEW 15 AMP 3 POLE CIRCUIT BREAKER TO FEED EXHAUST FAN 2B IN SPACE AVAILABLE IN PANEL 2AH1 (GE MODEL # HNB). MATCH AIC RATING OF EXISTING CIRCUIT BREAKERS. PROVIDE AND INSTALL 3 #12 CONDUCTORS AND #12 GROUND IN 3/4" CONDUIT TO DISCONNECT SWITCH.
2. DISCONNECT EXISTING 15 AMP 3 POLE CIRCUIT BREAKER FEEDING EXISTING EXHAUST FAN 3 IN PANEL 2BH1 . REUSE EXISTING 15 AMP 3 POLE CIRCUIT BREAKER TO FEED EXHAUST FAN 3A. PROVIDE AND INSTALL 3 #12 CONDUCTORS AND #12 GROUND IN 3/4" CONDUIT TO DISCONNECT SWITCH. PROVIDE NEW 15 AMP 3 POLE CIRCUIT BREAKER TO FEED EXHAUST FAN 3B IN SPACE AVAILABLE IN PANEL 2BH1 (GE MODEL # HNB). MATCH AIC RATING OF EXISTING CIRCUIT BREAKERS. PROVIDE AND INSTALL 3 #12 CONDUCTORS AND #12 GROUND IN 3/4" CONDUIT TO DISCONNECT SWITCH.



KEY PLAN

PROJECT NORTH

1 / E201 WING A & B 2ND FLOOR ELECTRICAL NEW WORK PLAN
SCALE: 1/8" = 1'-0"

Revisions	Date

Northeast Infrastructure LLC
630 Park Street
Honesdale, PA 18431
570.253.2245 570.251.9551 fax
www.neinfra.com
Service Disabled
Veteran Owned
Small Business

AGRRIS ENGINEERING GROUP LTD.
SUITE 722
67 PUBLIC SQUARE
WILKES-BARRE, PA 18701
TEL: (570) 825-7760
FAX: (570) 825-9001

Professional Seal
STATE OF NEW YORK · DALE L. ENGLEHART · 090021 · LICENSED PROFESSIONAL ENGINEER

Drawing Title
WING A & B 2ND FLOOR ELECTRICAL NEW WORK PLAN

Project Title
VAMC BATH EXHAUST FAN B-104

Building No. 104 | Checked D.L.E. | Drawn D.J.P.

Location
BATH, NEW YORK

Date 02/03/2014
Project No. 528A6-13-619
DRAWING NO. E201
Dwg. 3 Of 4

V.A.