


RFI FORM

Contractor Name: Herrera Corporation

Address:

Phone/eMail: John@thehcorp.com

Send to: Mandy.Thompson2@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	570-14-101	RFI NO.:	11
PROJECT NAME:	Parking Lot Re-stripe	DATE REQUESTED:	2/7/14
SOLICITATION NO.:	VA261-14-B-0192	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	01 45 29 3.18
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Spec section 01 45 29 3.18-Types of Tests- It calls out (2) sets of concrete sample. With the small amount of concrete being provided, why are (2) sets required?			
PROJECT MANAGER'S RESPONSE			
There will be no concrete samples required for the amount of work being accomplished on this project.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: 		DATE: 2/12/2014	


RFI FORM

Contractor Name: Herrera Corporation

Address:

Phone/eMail: John@thehcorp.com

Send to: Mandy.Thompson2@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	570-14-101	RFI NO.:	12
PROJECT NAME:	Parking Lot Re-stripe	DATE REQUESTED:	2/7/14
SOLICITATION NO.:	VA261-14-B-0192	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	01 57 19-EP-4
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Spec section 01 57 19.EP-4: Due to the short completion schedule and for bidding purposes, is a 'Environmental Protection Plan' required to be submitted and approved prior to the beginning of work?			
PROJECT MANAGER'S RESPONSE			
Duplicate to RFI 010			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: 		DATE: 2/12/2014	


RFI FORM

Contractor Name: Herrera Corporation

Address:

Phone/eMail: John@thehcorp.com

Send to: Mandy.Thompson2@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	570-14-101	RFI NO.:	13
PROJECT NAME:	Parking Lot Re-stripe	DATE REQUESTED:	2/7/14
SOLICITATION NO.:	VA261-14-B-0192	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	01 74 19-1.5B
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Spec section 01 74 19-1.5B: Due to the short completion schedule and for bidding purposes, is a 'Waste Management Plan' required to be submitted and approved prior to the beginning of work? Is a 'Diversion Report' going to be required for the minimal amount of concrete demo?			
PROJECT MANAGER'S RESPONSE			
A submittal is not required for 'WASTE MANAGEMENT PLAN' or 'Diversion Report'. The CONTRACTOR is responsible to comply with spec. Section 01 74 19 as it applies to this project.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: 		DATE: 2/12/2014	


RFI FORM

Contractor Name: Herrera Corporation

Address:

Phone/eMail: John@thehcorp.com

Send to: Mandy.Thompson2@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	570-14-101	RFI NO.:	14
PROJECT NAME:	Parking Lot Re-stripe	DATE REQUESTED:	2/7/14
SOLICITATION NO.:	VA261-14-B-0192	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	31 20 00
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Spec section 31 20 00: This section appears to be a boiler plate spec referring to among things as building earthwork, borrowing material, rock excavation, removal of trees and stumps, grading earth floors in basements etc. These do not apply to this project. What items in this section are pertinent for bidding purposes?			
PROJECT MANAGER'S RESPONSE			
Spec. Section 31 20 00 does not apply to the project.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: 		DATE: 2/11/2014	


RFI FORM

Contractor Name: Herrera Corporation

Address:

Phone/eMail: John@thehcorp.com

Send to: Mandy.Thompson2@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	570-14-101	RFI NO.:	15
PROJECT NAME:	Parking Lot Re-stripe	DATE REQUESTED:	2/7/14
SOLICITATION NO.:	VA261-14-B-0192	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	32 05 23 2.5
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Spec section 32 05 23 2.5: Confirm that liquid curing compound can be used on this project as opposed to burlap sack curing methods as required on other Fresno VA project.			
PROJECT MANAGER'S RESPONSE			
Liquid curing is an acceptable method.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: 		DATE: 2/11/2014	