


RFI FORM

Contractor Name: Herrera Corporation

Address:

Phone/eMail: John@thehcorp.com

Send to: Mandy.Thompson2@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	570-14-101	RFI NO.:	18
PROJECT NAME:	Parking Lot Re-stripe	DATE REQUESTED:	2/7/14
SOLICITATION NO.:	VA261-14-B-0192	REFERENCE:	
DRAWING:	005	SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Per sheet 006, provide detail for sign base install to include height of finished sign, how far off of curb face signs to be installed, and depth and width of bases.			
PROJECT MANAGER'S RESPONSE			
Set back 5" off of the expansion joint at back of curb, 2.375" galvanized steel posts imbedded up to 3.5", but to a minimum of 2' deep. See Attached Drawings for typical height of sign.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: 		DATE: 2/12/2014	

STOP SIGN DETAIL

