

Team West Contracting

1611 Jenks Drive, Corona, CA 92880

(951)340-3426 Fax (951)340-3428

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	691A4-13-115SM	RFI #:	1
Project Name:	Repair Roadways and Potholes for Sepulveda	Date Requested:	02-13-14
Solicitation No.:	VA-262-14-B-0231	Reference:	
Drawing:	GC001	Specification Section:	

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

Please be as specific as possible.

Will we be able to work an entire Phase at one time or will each Phase be broken into smaller areas? Phase I for example, will we be allowed to close and complete the road from the Plummer entrance up to Phase I-A in one move? Will we be able to start the next Phase during the 30 day cure period of the new pavement before we can sealcoat?

OWNER RESPONSE

One Phase at a time. Each phase must be completely finished before the contractor can work on the next phase.

KAL Architects Feb 19, 2014

OWNER TRACKING No.:

AMEND No.:

VA Project Engineer/Manager:

Date:

Team West Contracting

1611 Jenks Drive, Corona, CA 92880
(951)340-3426 Fax (951)340-3428

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	691A4-13-115SM	RFI #:	2
Project Name:	Repair Roadways and Potholes for Sepulveda	Date Requested:	02-13-14
Solicitation No.:	VA-262-14-B-0231	Reference:	
Drawing:		Specification Section:	01 00 00-7 (I)

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

Please be as specific as possible.

01 00 00-7 Item I states that we are to provide temporary chain link fencing "around the construction area indicated on the drawings." We did not see any areas specifically indicated on the drawings for fencing. Are we to fence in each Phase? If required to fence in each Phase, for example Phase I will cut off access from Building 200 to Buildings 1, 24, 22, 21 and 7.

OWNER RESPONSE

Use Phasing border as shown on the phasing plan, sheet GC001 to provide chain link fencing.

Yes, Each phase will be required to have fencing during the construction. Split Phase I and IA to avoid access blocking to any existing buildings. Coordinate with VA.

KAL Architects Feb 19, 2014

OWNER TRACKING No.:

AMEND No.:

VA Project Engineer/Manager:

Date:

Team West Contracting

1611 Jenks Drive, Corona, CA 92880

(951)340-3426 Fax (951)340-3428

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	691A4-13-115SM	RFI #:	3
Project Name:	Repair Roadways and Potholes for Sepulveda	Date Requested:	02-13-14
Solicitation No.:	VA-262-14-B-0231	Reference:	
Drawing:		Specification Section:	

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

Please be a specific as possible.

Will a lay down area sufficient to stockpile material and store equipment be provided?

OWNER RESPONSE

Contrator lay down area is located between Building #7, parking Lot X, the running track, and the Golf Course

OWNER TRACKING No.:

AMEND No.:

VA Project Engineer/Manager:

Steve Barrell

Date:

2/21/2014

Team West Contracting

1611 Jenks Drive, Corona, CA 92880

(951)340-3426 Fax (951)340-3428

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	691A4-13-115SM	RFI #:	4
Project Name:	Repair Roadways and Potholes for Sepulveda	Date Requested:	02-13-14
Solicitation No.:	VA-262-14-B-0231	Reference:	
Drawing:		Specification Section:	01 00 00-14

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

Please be as specific as possible.

01 00 00-14 1.12 Physical Data calls for a minimum of 2 borings 15 feet deep and test pits. Will this be required and if so how many test pits? What areas will these be required in?

OWNER RESPONSE

Yes. Coordinate with project registered surveyor or registered engineer for the test pits requirements.

KAL Architects Feb 19, 2014

OWNER TRACKING No.:

AMEND No.:

VA Project Engineer/Manager:

Date:

Team West Contracting

1611 Jenks Drive, Corona, CA 92880
(951)340-3426 Fax (951)340-3428

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	691A4-13-115SM	RFI #:	5
Project Name:	Repair Roadways and Potholes for Sepulveda	Date Requested:	02-13-14
Solicitation No.:	VA-262-14-B-0231	Reference:	
Drawing:		Specification Section:	01 00 00-14

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

Please be a specific as possible.

01 00 00-14 1.13 Professional Surveying Services. Since we are restoring the existing lines and elevations will this be required?

OWNER RESPONSE

Yes

KAL Architects Feb 19, 2014

OWNER TRACKING No.:

AMEND No.:

VA Project Engineer/Manager:

Date:

Team West Contracting

1611 Jenks Drive, Corona, CA 92880
(951)340-3426 Fax (951)340-3428

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	691A4-13-115SM	RFI #:	6
Project Name:	Repair Roadways and Potholes for Sepulveda	Date Requested:	02-13-14
Solicitation No.:	VA-262-14-B-0231	Reference:	
Drawing:		Specification Section:	01 00 00-19

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

Please be as specific as possible.

01 00 00-19 1.21 Photographic Documentation. Will this be required on such a small project? Will the Project Superintendent be able to take the photographs through out the project duration?

OWNER RESPONSE

Yes. Coordinate with VA. It may required security permit to take the photographs.

KAL Architects Feb 19, 2014

OWNER TRACKING No.:

AMEND No.:

VA Project Engineer/Manager:

Date:

Team West Contracting

1611 Jenks Drive, Corona, CA 92880

(951)340-3426 Fax (951)340-3428

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	691A4-13-115SM	RFI #:	7
Project Name:	Repair Roadways and Potholes for Sepulveda	Date Requested:	02-13-14
Solicitation No.:	VA-262-14-B-0231	Reference:	
Drawing:	CP-2	Specification Section:	

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

Please be as specific as possible.

The plans refer to "Slurry Seal." Please clarify whether this Type II aggregate slurry (which is not commonly put on new paving) or a sealcoat like Guard Top or equivalent? If it is sealcoat please specify 1 or 2 coats.

OWNER RESPONSE

The plans refer to slurry seal when repairing existing pavement. The contractor shall use Type II aggregate slurry.

KAL Architects Feb 19, 2014

OWNER TRACKING No.:

AMEND No.:

VA Project Engineer/Manager:

Date: