

## **STATEMENT OF WORK**

### **A. GENERAL INFORMATION**

1. Title of Project Purchase 12 New AGM Batteries
2. Scope of Work: Deliver and set in place batteries for Generators, to include removal and disposal of old batteries.
3. Background: The Current batteries are at the end of their life cycle.
4. Performance Period: The contractor shall complete the work required under this SOW during normal business hours 0700- 1500) period of no longer than 1 Day unless otherwise directed by the Contracting Officer (CO).
5. Type of Contract: Firm-Fixed-Price

### **B. GENERAL REQUIREMENTS**

The Vendor shall Deliver, unload and set in place the new batteries, said vendor will also be responsible for removal and disposal of the old batteries

**SCHEDULED MAINTENANCE: N/A**

### **ITEMS TO BE SUPPLIED BY THE CONTRACTOR**

1. Vendor shall supply 12 High premium output absorbed glass mat typically (AGM) maintenance free batteries at 12 volts with 1400 cold cranking AMPS each.
2. The contractor shall be responsible for protecting the personnel furnishing services under this contract. The parties agree that the contractor, its employees, agents and subcontractors shall not be considered VA employees for any purpose. Except in emergencies and as directed by the COTR

### **INSPECTION AND TESTING SERVICES**

Vendor shall test and inspect each battery prior to leaving the delivery site to insure proper charge and operation of batteries. VA Engineering representative shall inspect and accept batteries prior to signing any document from vendor.

### **F. GOVERNMENT RESPONSIBILITIES**

The VA shall grant the Contractor and its Subcontractor permission to required areas of the Ralph H. Johnson VA Medical Center for the purpose deliver and setup of batteries.

Ralph H. Johnson VAMC