


- NOTES:
1. LOCATE ALL ZONE WATER FLOW ASSEMBLIES AT AN ACCESSIBLE LOCATION IN THE STAIRWAYS.
  2. SEE SPECIFICATIONS FOR SPACING DISTANCE OF FLOW SWITCH IN REFERENCE TO FITTINGS, ETC.

TYPICAL ZONE FLOW ALARM

---

NOT TO SCALE

"AS BUILT" Revisions	6/17/94 Date
	 Robert A. Geyer
<div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <b>RECORD DRAWING</b>          CORRECTED ON BASIS OF DATA          FURNISHED BY THE RESIDENT ENGINEER       </div>	
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p>RTKL/CSD/HENRY ADAMS (J.V.)            ARCHITECTS AND ENGINEERS            400 E. PRATT STREET            BALTIMORE, MD 21202</p> </div> <div style="width: 45%;"> <p>HENRY ADAMS, INC.            Consulting Engineers            Baltimore, Maryland</p> </div> </div>	
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p><b>FIRE PROTECTION DETAILS &amp; SECTIONS PLUMBING</b></p> </div> <div style="width: 45%;"> <p><b>Approved Project Director</b></p> <p style="text-align: center;"><i>Robert Miller</i></p> </div> </div>	
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p><b>Project Title</b></p> <p><b>324 - BED REPLACEMENT HOSPITAL - PHASE II</b></p> </div> <div style="width: 45%;"> <p><b>Scale</b></p> <p><b>AS NOTED</b></p> </div> </div>	
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p><b>Project No.</b></p> <p><b>511-001D</b></p> </div> <div style="width: 45%;"> <p><b>Building Number</b></p> <p><b>1</b></p> </div> </div>	
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p><b>Date</b></p> <p><b>9/1/88</b></p> </div> <div style="width: 45%;"> <p><b>Drawing No.</b></p> <p><b>I-P66</b></p> </div> </div>	
<p><b>Location</b></p> <p><b>VAMC - BALTIMORE, MD.</b></p>	
<p><b>Dwg. 63 0174</b></p>	