

**ADDENDUM NO. ONE (1)**  
**Miles City VA**  
**Asbestos Abatement**

Date: February 18, 2014

Bid Date: Bid Date

TO: ALL PLANHOLDERS

The plans and specifications for the above captioned project are hereby modified and/or superseded by this Addendum:

**SPECIFICATIONS –**

No changes at this time.

**DRAWINGS –**

Drawing HA404:

- Corridor 252
  - Move the arrow pointing to room 265 to room 252.
  - Change Floor Tile Quantity from 1,000 square feet to 710.
- Waiting Area 252A - Change Floor Tile Quantity from 350 square feet to 765 square feet.

Drawing HA405:

- Corridor 213 – This area should be hatched. The area is 680 square feet. The tile contains asbestos; the mastic does not contain asbestos. Replace with new tile.

Drawing HA407:

- Corridor 234 – This area should be hatched. The area is 650 square feet. The tile contains asbestos; the mastic does not contain asbestos. Replace with new tile.

Drawing HA410:

- Corridor 136 - Change Floor Tile Quantity from 1,050 square feet to 3,650 square feet.

Drawing HA412:

- Secretary 131 – Change Floor Tile Quantity from 1,100 square feet to 3,200 square feet

END OF ADDENDUM NO. ONE