Name/Suffix	Address	Description	Value/State	Status	Priority
LOI.64.DPU.LIGHT.MAND	0301.55.01	( )	230.43 KW	As	NONE
LOI.64.DPU.LIGHT.FACTOR	0301.55.03	(AVCS-DCP)		OFF	As NONE
LOI.64.DPU.LIVLOSSE.N.N	0301.56.01	(AVCS-DCP)	272.33 VOLTS	As	NONE
LOI.64.DPU.LIVLOSSE.N.S	0301.56.02	(AVCS-DCP)	270.33 VOLTS	As	NONE
LOI.64.DPU.LIVLOSSE.CN	0301.56.03	(AVCS-DCP)	271.33 VOLTS	As	NONE
LOI.64.DPU.LOWQUIPPLY.H1	0301.56.09	(TRANSFER UNIT)	870582 KWH	**	NONE
LOI.64.DPU.LOWQUIPPLY.LO	0301.56.10	(TRANSFER UNIT)	30582 KWH	**	NONE
LOI.64.DPU.LOWPWR.F	0301.56.11	(TRANSFER UNIT)	0 KW	**	NONE
LOI.64.DPU.LOWPWR.H1	0301.56.12	( )	0.00 KW	**	NONE
LOI.64.DPU.LOWPWR.LO	0301.56.13	( )	0.00 AMPS	**	NONE
LOI.64.DPU.LOWPWR.F	0301.56.14	( )	0.00 AMPS	**	NONE
LOI.64.DPU.LOWPWR.F	0301.56.15	( )	0.00 AMPS	**	NONE
LOI.64.DPU.DAY.NSE	0301.56.19	( )	DAY	**	NONE
LOI.64.DPU.LOSSEN.MND	0301.56.20	( )	1.00 KW	**	NONE
LOI.64.DPU.UPPOWR.FACTOR	0301.56.21	(TRANSFER UNIT)		OFF	** NONE
LOI.64.DPU.LOSSTAGE.N.N	0301.56.22	(TRANSFER UNIT)	124.53 VOLTS	**	NONE
LOI.64.DPU.LOSSTAGE.N.N	0301.56.22	(TRANSFER UNIT)	124.53 VOLTS	**	NONE
LOI.64.DETXCS.N.JOB.STS	0317.00.00	(SF.SW.STATUS)	ON	As	NONE
LOI.64.DETXCS.N.JOB.STS	0317.00.00	(SF.SW.STATUS)	ON	As	NONE
LOI.64.DETXCS.N.JOB.STS	0317.00.00	(SF.SW.STATUS)	ON	As	NONE
LOI.64.DETXCS.STAT.TEMP.N	0317.00.01	(DEHUMIDIFY)	NORMAL	As	NONE
LOI.64.DR.COMF.TEMP.HI.CWV	0317.00.02	(CHW VALVE)	33.00 PSI	As	NONE
LOI.64.DR.COMF.TEMP.HI.CWV	0317.00.02	(FLOW STATUS)	ON	As	NONE
LOI.64.DR.COMF.TEMP.HI.RVT	0317.00.02	(ROOM TEMP)	72.50 DEGF	As	NONE
LOI.64.DR.COMF.TEMP.HI.DEL	0317.17.00	(RVAV) TEMP)	OFF	As	NONE
LOI.64.DOOR.DSC.HW.SWT	0317.00.08	(HW DR STAT)	55.00 DEGF	As	NONE
LOI.64.DOOR.DSC.HW.CLOSE	0317.00.09	(DOOR CLOSE)	ON	As	NONE
LOI.64.EF.22.STS	0317.00.00	(EF.22.STATUS)	ON	As	NONE
LOI.64.EF.22.SWT	0317.00.00	(EF.22.STATUS)	ON	As	NONE
LOI.64.EF.SUMP.ALARM	0317.00.00	(SUMP ALARM)	OFF	As	NONE
LOI.64.EF.SUMP.FILTER	0317.00.00	(EF.SUMP.FILTER)	ON	As	NONE
LOI.64.EF.SUMP.FILTER.ALM	0317.00.00	(EF.SUMP.FILTER.ALM)	OFF	As	NONE
LOI.64.EF.SUMP.FILTER.ALM.SYSTEM	0317.00.00	(EF.SUMP.FILTER.ALM)	OFF	As	NONE
LOI.64.EF.TEMP.FILTER.ALM	0317.00.00	(EF.TEMP.FILTER.ALM)	OFF	As	NONE
LOI.64.EF.SU