

December 14, 2011

Mr. Wilson Rowley
VA San Diego
Dept. of Engineering

Re: **Lead Bulk Sample Results – Emergency Dept. Upgrade, First Floor**
Inside Secondary Containment, Steel Framework Girder
Millennium Project: 5015.2482

Mr. Rowley:

Millennium Consulting Associates (Millennium) collected a bulk sample at the direction of the VA San Diego, at the above referenced location. The sample was analyzed under SW 846 305B/7000B) for lead.

Results indicated that the sample (sample number 0001) contained 38% or 380,000 mg/kg (ppm) of lead. This material requires special handling, training and personal protection if the lead coating is disturbed or removed. A copy of the results are attached.

If you have any questions, please contact me directly at (925) 808-6700. Thank you.

Sincerely,



Michael Noel CIH
President
Millennium Consulting Associates
(925) 808-6700



ERM

2251 San Diego Avenue
Suite 208 South
San Diego, CA 92109
(619) 574-0620
(619) 574-0624 (fax)

Environmental
Resources
Management

Inspection Type: PERIMETER Date: 12/15

1ST FLOOR

Inspected by: JOHN McCUBBIN

Project/Case Name: EMERGENCY DEPT. UPGRADE

Address: V.A. MEDICAL CENTER
LA JOLLA, CA.

Client: WILSON ROWLEY

ERM Job #

5015-2482

Photo	Image	Location	Notes
			RESULTS OF YESTERDAY'S LEAD SAMPLING HAVE BEEN DISTRIBUTED TO ALL CONCERNED (38%).
			A GENERAL WALKTHROUGH WITH DISCUSSION ON REMEDIATION WAS CONDUCTED WITH MR. WILSON & WIFE "HARVEY" (HEALTH & SAFETY) AND THE CONTRACTOR.
			OVERALL HOUSEKEEPING REMAINS GOOD, HOWEVER, THE ACCUMULATION OF DISCARDED/OBSCURE CANS AND GENERAL DEBRIS IS GROWING -
			MANOMETER READING - 0.004 (NO ABATEMENT IN PROCESS)

SAMPLE NO.	LOCATION	FLOW RATE	START TIME	STOP TIME	VOLUME	FIBRES	FIBRES/ FIELD	FIBRE C
1001	PERIMETER- HALLWAY BY PHARMACY DISPENSARY	12:01 LPM	6:05 A	8:35 A	1801.5L	3.5/100	.035	<0.0
1002	PERIMETER- HALLWAY BY RADIOLOGY DEPARTMENT	12:01 LPM	6:10 A	8:40 A	1801.5L	3/100	.03	<0.0
1003	PERIMETER- NEAR RESTROOMS IN EMERGENCY WAITING RM.	12:01 LPM	11:40 A	2:10 P	1801.5L	5/100	.05	<0.0
1004	PERIMETER- HALLWAY BY N/W EXIT DOORS	12:01 LPM	11:45 A	2:15 P	1801.5L	4.5/100	.045	<0.0

Sample Media: PCM



Environmental
Resources
Management

ERM

2251 San Diego Avenue
Suite 208 South
San Diego, CA 92109
(619) 574-0620
(619) 574-0624 (fax)

Inspection Type: PERIMETER Date: 12/14/11

1ST FLOOR

Inspected by: JOHN MCCUBBIN

Project/Case Name: EMERGENCY DEPT. URG.

Address: V.A. MEDICAL CENTER
LA JOLLA, CA.

Client: WILSON ROWLEY

ERM Job # 5015-2482

Photo	Image	Location	Notes
			PROJECT MOVING ALONG RATHER SLOWLY AT THIS TIME - WAITING FOR RESULTS OF YESTERDAY LEAD (Pb) SAMPLING - HOUSEKEEPING REMAINS GOOD - SOME DEBRIS IS HEAVILY PILED AT NORTH/WEST CORNER AREA FOR LATER GENERAL TRASH DISPOSAL - NO VISIBLE HAZARDS NOTED AT THIS TIME

SAMPLE NO.	LOCATION	FLOW RATE	START TIME	STOP TIME	VOLUME	FIBRES	FIBRES/ FIELD	FIBRE C
1001	PERIMETER- BY ENTRY TO RADIOLOGY	12.01 LPM	9:55A	12:25P	1801.5L	4/100	.04	<0.0
1002	PERIMETER- NEAR N/W EXIT DOORS	12.01 LPM	10:06A	12:30P	1801.5L	6.5/100	.065	<0.0
1003	PERIMETER- NEAR PHARMACY DISPENSARY	12.01 LPM	12:40P	3:10P	1801.5L	5/100	.05	<0.0
1004	PERIMETER- BY REST- ROOMS- EMER. WGT. RM.	12.01 LPM	12:45P	3:15P	1801.5L	5.5/100	.055	<0.0

Sample Media: PCM

MILLENNIUM
CONSULTING ASSOCIATES
A MECA Consulting, Inc. Company

"Providing Premiere Environmental & Industrial Hygiene Services Since 1986"

Corporate Offices:
620 Contra Costa Blvd., Ste. 102
Pleasant Hill, CA 94523
925.808.6700
www.mecaenviro.com

December 14, 2011

Mr. Wilson Rowley
VA San Diego
Dept. of Engineering

Re: Lead Bulk Sample Results – Emergency Dept. Upgrade, First Floor
Inside Secondary Containment, Steel Framework Girder
Millennium Project: 5015.2482

Mr. Rowley:

Millennium Consulting Associates (Millennium) collected a bulk sample at the direction of the VA San Diego, at the above referenced location. The sample was analyzed under SW 846 305B/7000B) for lead.

Results indicated that the sample (sample number 0001) contained 38% or 380,000 mg/kg (ppm) of lead. This material requires special handling, training and personal protection if the lead coating is disturbed or removed. A copy of the results are attached.

If you have any questions, please contact me directly at (925) 808-6700. Thank you.

Sincerely,



Michael Noel CIH
President
Millennium Consulting Associates
(925) 808-6700



LA Testing

520 Mission Street, South Pasadena, CA 91030

Phone: (323) 254-6900 Fax: (323) 254-6837 Email: pasadenalab@latesting.com

Attn: **Mike Noel**
Millennium Consulting Associates, Inc.
620 Contra Costa Blvd.
Suite 102
Pleasant Hill, CA 94523

Customer ID: MECA62
Customer PO: #8889
Received: 12/14/11 9:00 AM
LA Testing Order: 321120383


Fax: (925) 808-6708 Phone: (925) 808-6700
Project: Emergency Dept. Upgrade-Job#5015-2482

LA Testing Proj:

Test Report: Lead in Paint Chips by Flame AAS (SW 846 3050B*7000B)

Lab ID:	Analyzed	RDL	Lead Concentration	Notes
0001	12/14/2011	0.010 % wt	38 % wt	Site: Inside Secondary Containment
Client Sample 1001				Collected: 12/13/2011

Initial report from 12/14/2011 13:24:31


Jerry Drapala Ph.D, Laboratory Manager
or other approved signatory

Reporting limit is 0.01 % wt. The QC data associated with these sample results included in this report meet the method quality control requirements, unless specifically indicated otherwise. Unless noted, results in this report are not blank corrected. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities.

* slight modifications to methods applied Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted.

Samples analyzed by LA Testing South Pasadena, CA CA ELAP 2283, AIHA-LAP, LLO ELLAP 102814

321120383



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Lead (Pb) Chain of Custody

EMSL Order ID (Lab Use Only):

321120383

EMSL ANALYTICAL, INC.
3 COOPER STREET
WESTMONT, NJ 08108
PHONE: (856) 858-4800
FAX: (856) 858-3899

Company: Millennium Consulting Associates		EMSL-Bill to: <input checked="" type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments**	
Street: 620 Contra Costa Blvd., Ste 102		Third Party Billing requires written authorization from third party	
City: Pleasant Hill	State/Province: CA	Zip/Postal Code: 94523	Country: USA
Report To (Name):		Fax #: (925) 808-6708	
Telephone #: (925) 808-6700		Email Address: frontdesk@mecaenviro.com , mnoel@mecaenviro.com	
Project Name/Number: EMERGENCY DEPT. UPGRADE - JOB # 5015-2482			
Please Provide Results: <input checked="" type="checkbox"/> Fax <input checked="" type="checkbox"/> Email		Purchase Order: # 6889 U.S. State Samples Taken:	
Turnaround Time (TAT) Options* - Please Check			
<input type="checkbox"/> 3 Hour	<input checked="" type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input type="checkbox"/> 2 Week
*Analysis completed in accordance with EMSL's Terms and Conditions located in the Price Guide			
Matrix	Method	Instrument	Reporting Limit
Chips <input type="checkbox"/> mg/cm ² <input checked="" type="checkbox"/> % by wt.	SW846-7000B/7420 or AOAC 974.02	Flame Atomic Absorption	0.01%
Air	NIOSH 7082	Flame Atomic Absorption	4 µg/filter
	NIOSH 7105	Graphite Furnace AA	0.03 µg/filter
	NIOSH 7300 modified	ICP-AES	0.5 µg/filter
Wipe* <input type="checkbox"/> ASTM <input type="checkbox"/> non ASTM *if no box is checked, non-ASTM Wipe is assumed	SW846-7000B/7420	Flame Atomic Absorption	10 µg/wipe
	SW846-6010B or C	ICP-AES	0.5 µg/wipe
TCLP	SW846-1311/7420/SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW846-6010B or C	ICP-AES	0.1 mg/L (ppm)
Soil	SW846-7000B/7420	Flame Atomic Absorption	40 mg/kg (ppm)
	SW846-7421	Graphite Furnace AA	0.3 mg/kg (ppm)
	SW846-6010B or C	ICP-AES	1 mg/kg (ppm)
Wastewater	SM3111B or SW846-7000B/7420	Flame Atomic Absorption	0.4 mg/L (ppm)
	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)
	SW846-6010B or C	ICP-AES	1 mg/kg (ppm)
Drinking Water	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)
Other:		Preservation Method (Water):	
Name of Sampler: JOHN McCUBBIN		Signature of Sampler: <i>[Signature]</i>	
Sample #	Location	Volume/Area	Date/Time Sampled
1001	INSIDE SECONDARY CONTAINMENT	APPROX. 1 SQ. FT.	12/13/11 9:05A
Client Sample #'s		Total # of Samples:	
Relinquished (Client): <i>[Signature]</i>	Date: 12/13/11	Time:	
Received (Lab): <i>[Signature]</i>	Date: 12/13/11	Time:	9:46 am
Comments: <i>Rec'd by K. Lee 12/14/11 9:00am</i>			