

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No Mfg Model  
 400 UNK UNK-O

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1" H 110 2 OK

In/Out Equip  
 I

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out DR

Location: BOILER PLANT STEAM HEADER

Comments:

Tag No Mfg Model  
 401 UNK UNK-O

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1" H 110 2 RC

In/Out Equip  
 I

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out DR

Location: BOILER PLANT STEAM HEADER

Comments: WGT

Tag No Mfg Model  
 402 UNK UNK-O

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 3/4" H 110 3 OK

In/Out Equip  
 I

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out DR

Location: BOILER PLANT CHILLER ROOM

Comments:

Tag No Mfg Model  
 403 UNK UNK-O

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 3/4" H 30 8 OS

In/Out Equip  
 I

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out DR

Location: BOILER PLANT CHILLER ROOM

Comments:

Tag No Mfg Model  
 404 UNK UNK-O

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" H 30 8 OS

In/Out Equip  
 I UH

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out CL

Location: BOILER PLANT CHILLER ROOM

Comments: 1X1

Tag No Mfg Model  
 405 UNK UNK-O

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" H 30 8 OS

In/Out Equip  
 I UH

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out CL

Location: BOILER PLANT CHILLER ROOM

Comments: 1X1

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
406	UNK	UNK-O	3/4"	H	110		7	BT

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT SUB BASEMENT

Comments: WGT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
407	STL	INL AM	3/4"	H	30		7	BT

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	UH	1	1	1			CL

Location: BOILER PLANT CORNER SUB BASEMENT

Comments: WGT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
408	STL	INL AM	3/4"	H	30		7	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT CORNER SUB BASEMENT

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
409	STL	INL AM	3/4"	H	30		2	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT CORNER SUB BASEMENT

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
410	STL	INL AM	3/4"	H	30		0	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT CORNER SUB BASEMENT

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
411	STL	INL AM	3/4"	H	30		1	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT CORNER SUB BASEMENT

Comments:

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
412	STL	INL AM	3/4"	H	30		1	LK

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT CORNER SUB BASEMENT

Comments: WGT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
413	STL	INL AM	1/2"	H	30		6	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT MEZZ LEVEL

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
414	STL	INL AM	1"	H	110		1	LK

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT MAIN FLOOR STEAM HEADER

Comments: WGT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
415	STL	INL AM	1"	H	110		1	FL

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT MAIN FLOOR STEAM HEADER

Comments: WGT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
416	STL	INL AM	1"	H	30		7	FL

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BOILER PLANT BY WINDOW

Comments: WGT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
417	STL	INL AM	1"	H	30		20	OK

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	UH	1	1	1			CL

Location: BOILER PLANT BY ENTRANCE

Comments: 2X2

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No Mfg Model  
 418 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1" H 110 10 OS

In/Out Equip  
 I

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out DR

Location: BOILER PLANT ABV STEAM HEADER

Comments:

Tag No Mfg Model  
 419 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1" H 110 10 OS

In/Out Equip  
 I

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out DR

Location: BOILER PLANT ABV STEAM HEADER

Comments:

Tag No Mfg Model  
 420 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1" H 110 10 OS

In/Out Equip  
 I

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out DR

Location: BOILER PLANT ABV STEAM HEADER

Comments:

Tag No Mfg Model  
 421 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" H 30 6 FL

In/Out Equip  
 I

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out DR

Location: LAUNDRY MR

Comments: EOM / WGT

Tag No Mfg Model  
 422 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" H 100 5 OK

In/Out Equip  
 I

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out DR

Location: LAUNDRY MR BY TEMP WATER TANK

Comments:

Tag No Mfg Model  
 423 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 3/4" H 30 1 OS

In/Out Equip  
 I TH

V In Str V Out Line Line Appl  
 1 1 1 Sz In Sz Out PR

Location: LAUNDRY MR REUSE WATER TANK

Comments:

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No Mfg Model  
 424 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1" H 30 1 OS

In/Out Equip  
 I TH

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 PR

Location: LAUNDRY MR REUSE WATER TANK

Comments:

Tag No Mfg Model  
 425 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" H 30 6 OK

In/Out Equip  
 I

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 DR

Location: LAUNDRY MR REUSE WATER TANK

Comments:

Tag No Mfg Model  
 426 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" H 100 5 OK

In/Out Equip  
 I

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 DR

Location: LAUNDRY MR HOT WATER TANK

Comments:

Tag No Mfg Model  
 427 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1" H 100 1 FL

In/Out Equip  
 I TH

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 PR

Location: LAUNDRY MR HOT WATER TANK

Comments: WGT / REPIPING REQD

Tag No Mfg Model  
 428 SAR T25

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" A 30 7 OS

In/Out Equip  
 I UH

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 CL

Location: LAUNDRY BREAK ROOM

Comments: 1X1 / WGT

Tag No Mfg Model  
 429 SAR T25

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" A 30 7 OS

In/Out Equip  
 I UH

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 CL

Location: LAUNDRY WOMENS REST ROOM

Comments: 1X1 / WGT

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
430	SAR	T25	1/2"	A	30		7	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	UH	1	1	1			CL

Location: LAUNDRY WOMENS REST ROOM

Comments: 1X1 / WGT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
431	STL	INL AM	1/2"	H	30		7	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	UH	1	1	1			CL

Location: LAUNDRY SEWING ROOM

Comments: 1X1

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
432	STL	INL AM	1/2"	H	30		8	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: LAUNDRY SEWING ROOM

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
433	STL	INL AM	1"	H	100		5	OK

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BLDG 1 BASEMENT MR

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
434	STL	INL AM	3/4"	H	15		6	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BLDG 1 BASEMENT MR

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
435	STL	INL AM	3/4"	H	15		5	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BLDG 1 BASEMENT MR

Comments:

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
436	STL	INL AM	3/4"	H	15		5	OS
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	1			DR

Location: BLDG 1 BASEMENT MR

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
437	STL	INL AM	3/4"	H	15		5	OS
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	1			DR

Location: BLDG 1 BASEMENT MR

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
438	STL	INL AM	1"	H	100		5	OK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	1			DR

Location: BLDG 1 BASEMENT MR

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
439	STL	INL AM	3/4"	H	15		5	OK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	1			DR

Location: BLDG 1 BASEMENT MR

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
440	UNK	UNK	1-1/2"	O	15		2	OK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	FT		1	1	1			DR

Location: BLDG 1 BASEMENT MR

Comments: UNK FT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
441	UNK	UNK	1-1/4"	O	15		0	OK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	FT		1	1	1			DR

Location: BLDG 1 BASEMENT MR

Comments: UNK FT

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No Mfg Model  
 442 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1" H 100 1 OK

In/Out Equip  
 I

V In Str V Out Line Sz In Line Sz Out Appl  
 1 1 1 DR

Location: BLDG 1 BASEMENT MR

Comments:

Tag No Mfg Model  
 443 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 3/4" H 100 1 FL

In/Out Equip  
 I

V In Str V Out Line Sz In Line Sz Out Appl  
 1 1 1 DR

Location: BLDG 1 BASEMENT MR

Comments: OVER RECEIVER / WGT

Tag No Mfg Model  
 444 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 3/4" H 15 7 OS

In/Out Equip  
 I UH

V In Str V Out Line Sz In Line Sz Out Appl  
 1 1 1 CL

Location: BLDG 1 1ST FLOOR MR

Comments:

Tag No Mfg Model  
 445 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 3/4" H 30 1 OK

In/Out Equip  
 I

V In Str V Out Line Sz In Line Sz Out Appl  
 1 1 1 DR

Location: CANTEEN DISHWASHER

Comments: DISH MACHINE

Tag No Mfg Model  
 446 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" H 30 2 OS

In/Out Equip  
 I

V In Str V Out Line Sz In Line Sz Out Appl  
 1 1 1 DR

Location: BLDG 1 1ST FLOOR MR

Comments:

Tag No Mfg Model  
 447 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1" H 30 1 FL

In/Out Equip  
 I HE

V In Str V Out Line Sz In Line Sz Out Appl  
 1 1 1 PR

Location: BLDG 1 RM 2639 MR 2ND FLOOR

Comments: NWH-2 / WGT



## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No Mfg Model  
 448 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 3/4" V 15 8 OK

In/Out Equip  
 I

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 DR

Location: BLDG 1 RM 2639 MR 2ND FLOOR  
 Comments: HEATER BY DOOR

Tag No Mfg Model  
 449 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 3/4" H 15 3 BT

In/Out Equip  
 I

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 DR

Location: BLDG 1 2ND FLOOR MR 2239  
 Comments: WGT

Tag No Mfg Model  
 450 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 3/4" H 100 2 OK

In/Out Equip  
 I

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 DR

Location: BLDG 1 2ND FLOOR MR 2239  
 Comments:

Tag No Mfg Model  
 451 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" H 30 1 FL

In/Out Equip  
 I HE

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 PR

Location: BLDG 1 3RD FLOOR KITCHEN DISHWASHER  
 Comments: WGT

Tag No Mfg Model  
 452 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" V 30 1 FL

In/Out Equip  
 I HE

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 PR

Location: BLDG 1 3RD FLOOR KITCHEN DISHWASHER  
 Comments: WGT

Tag No Mfg Model  
 453 STL INL AM

Conn Sz Pipe Dir PSI In PSI Out Elev Cond  
 1/2" V 30 1 FL

In/Out Equip  
 I HE

V In Str V Out Line Line  
 1 1 1 Sz In Sz Out Appl  
 PR

Location: BLDG 1 3RD FLOOR KITCHEN DISHWASHER  
 Comments: WGT

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
454	W-M	FT63	3/4"	S	30		3	OS
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	0	1			DR

Location: BLDG 1 3RD FLOOR MR #3627

Comments: REMOVE / TRAP USELESS

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
455	ARM	125A13	3/4"	S	100		1	OK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	0			DR

Location: BLDG 1 3RD FLOOR MR #3627

Comments: AMW GENERATOR

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
456	ARM	125A6	1-1/2"	O	30		1	OK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	HE		0	0	0			PR

Location: BLDG 1 3RD FLOOR MR #3627

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
457	STL	INL AM	1"	H	30		3	OS
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	HE		1	1	1			PR

Location: BLDG 1 3RD FLOOR MR #3627

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
458	STL	INL AM	1"	H	30		4	OS
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	HE		1	1	1			PR

Location: BLDG 1 3RD FLOOR MR #3627

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
459	STL	INL AM	3/4"	H	100		0	LK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	1			DR

Location: BLDG 1 3RD FLOOR MR #3627

Comments: WGT

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
460	STL	INL AM	3/4"	H	75		0	OK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	1			DR

Location: BLDG 1 3RD FLOOR MR #3627

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
461	STL	INL AM	3/4"	H	75		1	FL
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	1			DR

Location: BLDG 1 3RD FLOOR MR #3627

Comments: WGT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
462	STL	INL AM	3/4"	H	15		1	LK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	1			DR

Location: BLDG 1 3RD FLOOR MR #3627

Comments: WGT

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
463	STL	INL AM	1"	H	17		3	OK
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I			1	1	1			DR

Location: BLDG 1 7TH FLOOR PENTHOUSE

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
464	STL	INL AM	1"	H	17		3	OS
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	HE		1	1	1			PR

Location: BLDG 1 7TH FLOOR PENTHOUSE

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
465	STL	INL AM	1"	H	17		5	OS
In/Out	Equip		V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	HE		1	1	1			PR

Location: BLDG 1 7TH FLOOR PENTHOUSE

Comments:

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
466	STL	INL AM	3/4"	H	17		3	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BLDG 1 7TH FLOOR PENTHOUSE

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
467	STL	INL AM	3/4"	H	17		1	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BLDG 1 7TH FLOOR PENTHOUSE

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
468	SAR	T65	1/2"	H	17		0	BT

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I		1	1	1			DR

Location: BLDG 1 7TH FLOOR PENTHOUSE

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
469	STL	INL AM	1"	H	17		0	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	AHU	1	1	1			CL

Location: BLDG 1 7TH FLOOR PENTHOUSE

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
470	DUN	40-215A	3/4"	S	17		1	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	HE	0	0	0			PR

Location: BLDG 20 CLC RM 148

Comments:

Tag No	Mfg	Model	Conn Sz	Pipe Dir	PSI In	PSI Out	Elev	Cond
471	DUN	40-215A	3/4"	S	17		1	OS

In/Out	Equip	V In	Str	V Out	Line Sz In	Line Sz Out	Appl
I	HE	0	0	0			PR

Location: BLDG 20 CLC RM 148

Comments:

## TRAP SURVEY LOG SHEET REPORT

Survey No: VAM-004-0000  
 Resurvey No: R1  
 Location: GRAND JCT, CO  
 Customer: VA MEDICAL  
 CENTER

Survey Date(s): 7/10/2013  
 thru 7/10/2013

<u>Tag No</u>	<u>Mfg</u>	<u>Model</u>	<u>Conn Sz</u>	<u>Pipe Dir</u>	<u>PSI In</u>	<u>PSI Out</u>	<u>Elev</u>	<u>Cond</u>
472	STL	INL AM	3/4"	H	15		7	LK
<u>In/Out</u>	<u>Equip</u>		<u>V In</u>	<u>Str</u>	<u>V Out</u>	<u>Line Sz In</u>	<u>Line Sz Out</u>	<u>Appl</u>
I	UH		1	1	1			CL

Location: BLDG 20 CLC RM 148

Comments: WGT

<u>Tag No</u>	<u>Mfg</u>	<u>Model</u>	<u>Conn Sz</u>	<u>Pipe Dir</u>	<u>PSI In</u>	<u>PSI Out</u>	<u>Elev</u>	<u>Cond</u>
473	STL	INL AM	1"	H	15		1	OK
<u>In/Out</u>	<u>Equip</u>		<u>V In</u>	<u>Str</u>	<u>V Out</u>	<u>Line Sz In</u>	<u>Line Sz Out</u>	<u>Appl</u>
I	HE		1	1	1			PR

Location: BLDG 20 CLC RM 148

Comments:

<u>Tag No</u>	<u>Mfg</u>	<u>Model</u>	<u>Conn Sz</u>	<u>Pipe Dir</u>	<u>PSI In</u>	<u>PSI Out</u>	<u>Elev</u>	<u>Cond</u>
474	STL	INL AM	1"	H	15		2	OK
<u>In/Out</u>	<u>Equip</u>		<u>V In</u>	<u>Str</u>	<u>V Out</u>	<u>Line Sz In</u>	<u>Line Sz Out</u>	<u>Appl</u>
I			1	1	1			DR

Location: BLDG 20 CLC RM 148

Comments:

<u>Tag No</u>	<u>Mfg</u>	<u>Model</u>	<u>Conn Sz</u>	<u>Pipe Dir</u>	<u>PSI In</u>	<u>PSI Out</u>	<u>Elev</u>	<u>Cond</u>
475	STL	INL AM	1"	H	30		2	OK
<u>In/Out</u>	<u>Equip</u>		<u>V In</u>	<u>Str</u>	<u>V Out</u>	<u>Line Sz In</u>	<u>Line Sz Out</u>	<u>Appl</u>
I			1	1	1			DR

Location: BLDG 20 CLC RM 148

Comments:

<u>Tag No</u>	<u>Mfg</u>	<u>Model</u>	<u>Conn Sz</u>	<u>Pipe Dir</u>	<u>PSI In</u>	<u>PSI Out</u>	<u>Elev</u>	<u>Cond</u>
476	STL	INL AM	3/4"	V	15		2	LK
<u>In/Out</u>	<u>Equip</u>		<u>V In</u>	<u>Str</u>	<u>V Out</u>	<u>Line Sz In</u>	<u>Line Sz Out</u>	<u>Appl</u>
I			1	1	1			DR

Location: BLDG 20 CLC RM 148

Comments: WGT