

## PROPOSAL REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-14-R-0197

**NOTE:** ALL PRE-PROPOSAL INQUIRIES SHALL BE SUBMITTED VIA EMAIL TO [parvinder.brar@va.gov](mailto:parvinder.brar@va.gov) and/or [denise.groves@va.gov](mailto:denise.groves@va.gov) BY AN EDITABLE USE OF THIS FORM. Please identify, in numerical sequence, each set of inquiries that you send.

Question(s) is/are on the solicitation [ ]

Question(s) is/are on the drawings, specifications, technical data [ ] RFI 7 sheet M161 keynote 3

Company Name and Offeror: SF&A

From (person submitting question): Rick Gomez, PM

Date of Proposal Inquiry: 03-17-14

Phone Number: 559-213-0050

Proposal Inquiry: (Type inquiry below)

Proposal RFI # 7. What is the Horse power of the fan for the existing air handler serving the 5th, 6th and 7th floor?

Add additional as necessary

15hp.  
-Jon Schlundt, Teter, 3/19/14