

## PROPOSAL REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-14-R-0197

**NOTE:** ALL PRE-PROPOSAL INQUIRIES SHALL BE SUBMITTED VIA EMAIL TO [parvinder.brar@va.gov](mailto:parvinder.brar@va.gov) and/or [denise.groves@va.gov](mailto:denise.groves@va.gov) BY AN EDITABLE USE OF THIS FORM. Please identify, in numerical sequence, each set of inquiries that you send.

Question(s) is/are on the solicitation [  ]

Question(s) is/are on the drawings, specifications, technical data [  ]

Company Name and Offeror: SF and Associates

From (person submitting question): Bill Payne

Date of Proposal Inquiry: March 17, 2014

Phone Number: 209-752-9213

Proposal Inquiry: (Type inquiry below)

Proposal RFI #1 – Can VA provide the Fire Alarm panel location with make and model number for all fire alarm repair/modifications?

- Panel for B-200 is located at the ground floor central hallway across from the E&A Reception and Waiting GA-3A.
- Panel for B-203 is located at Basement Switch Gear Room BA-19.
- Both systems are Johnson Controls FACP NFS-3030. See attached “SFVA Fire Alarm system 2014”
- Fire alarm system as-built drawings no longer available and if available will not reflect the remodeling of the past 20 years.

Proposal RFI #2 – Reference Attachment G, is the chute to be capped off to the ground floor?

- Yes. The cap shall meet 2 hour fire rating.

Proposal RFI #3 - Reference Attachment H, how wide is the new walkway to be constructed?

- Thirty six inches.

ADDITIONAL NOTE:

- For Attachment C1, which is the Pull Station at B-200 front entrance, all conduits must be hidden. Exposed conduit will not acceptable.