

VA261-14-R-0383- COSS 646 Card Readers/Telecommunications Ports

RFI's and Government Response through 3/31/2014

Proposal RFI #1 – Can plenum rated cabling be used for all applications of this project? **Yes**

Proposal RFI #2 – Are the Card Readers for security access only? **Yes**

Proposal RFI#3 - Is the one Card Reader at main entrance door to operate both sliding doors? **No, just exterior door.**

Proposal RFI #4 - Are the additional telecommunications outlets in Room 1011, for telecommunications only, no data required? **No, they shall have both telephone and data like other outlets.**

Proposal RFI #5 - Is there room in the patch panels for the telecommunications and for any data required? **Yes**

Proposal RFI #6 - Is the contractor to make the terminations into the patch panels or just the drops into Room 1031? **Terminations into patch panels.**

Proposal RFI #7 - Will testing of the telecommunications cabling be required? **Yes**

Proposal RFI #8 - Specification sections were not attached to the RFP, will VA provide specifications? **Yes**