

Table 2: Blowing, Leaking, and Plugged Traps from the Survey

Tag	Application	Building / Floor / Room	Trap Location, Elevation	Manufacturer	Model	Type of Trap	System Pressure	Pipe Size	Conn Type	Result
96335	Radiator Trap	1 / 1st / 103	2nd Window On Left, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
96342	Radiator Trap	1 / 1st / 106	Under Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	L
96345	Radiator Trap	1 / 1st / 111	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
96353	Radiator Trap	1 / 1st / 114	Under Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96338	Radiator Trap	1 / 1st / 103A	Window On Left, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	L
96332	Radiator Trap	1 / 2nd / 205	Under Window, 0-5'	Barnes & Jones	122	90RT	7	1/2"	NPT	B
96354	Radiator Trap	1 / 2nd / 203A	Under Right Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
96357	Radiator Trap	1 / 2nd / 203F	Right Window, 0-5'	Hoffman	8C	90RT	7	1/2"	NPT	B
96326	Radiator Trap	1 / 2nd / Administrative Suite	At Entrance, 0-5'	Hoffman	8C	90RT	7	1/2"	NPT	B
96327	Radiator Trap	1 / 2nd / Administrative Suite	200C, 0-5'	Hoffman	8C	90RT	7	1/2"	NPT	P
96328	Radiator Trap	1 / 2nd / Administrative Suite	200D, 0-5'	Hoffman	8C	CAPS	7	1/2"	NPT	P
96329	Radiator Trap	1 / 2nd / Conference Rm	Left Corner, 0-5'	Hoffman	9	90RT	7	3/4"	NPT	B
96324	Radiator Trap	1 / 2nd / Director's Office	Back Wall, 0-5'	Hoffman	8C	CAPS	7	1/2"	NPT	P
103653	Radiator Trap	2 / 1st / 101	Back Wall Left, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103654	Radiator Trap	2 / 1st / 102	Back Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103638	Radiator Trap	2 / 1st / 132	Station 3, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
103643	Radiator Trap	2 / 1st / 138	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
103664	Radiator Trap	2 / 1st / 148	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
103660	Radiator Trap	2 / 1st / 149	Back Wall 2nd From Left, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
103633	Unit Heater	2 / 1st / 162	Overhead At Entrance, 5-10'	Hoffman	53	Float & Thermostatic	7	3/4"	NPT	B

111612	Radiator Trap	2 / 1st / 112B	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
111601	Radiator Trap	2 / 1st / 134A	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103647	Radiator Trap	2 / 1st / 144B	Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103648	Radiator Trap	2 / 1st / 144B	Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
111617	Radiator Trap	2 / 1st / 146 Phlebotomy	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111623	Radiator Trap	2 / 1st / 155 Chem Lab	3rd Rad In, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111624	Radiator Trap	2 / 1st / 155 Chem Lab	Middle Rad, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103656	Radiator Trap	2 / 1st / 159A	Back Wall Left, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103657	Radiator Trap	2 / 1st / 159A	Back Wall Middle, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
103634	Unit Heater	2 / 1st / 162B	Over Cabinet, 5-10'	Spirax Sarco	FT15	Float & Thermostatic	7	3/4"	NPT	B
111628	Radiator Trap	2 / 1st / Men's Rm By Lobby	Under Window In Stall, 0-5'	Hoffman	17C	90RT	7	1/2"	SW	B
103642	Radiator Trap	2 / 1st / Stair 2	At Exit, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111634	Unit Heater	2 / 2nd / 162	In McQuay Unit, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114756	Radiator Trap	2 / 2nd / 204	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114758	Radiator Trap	2 / 2nd / 205	Under Window, 0-5'	Hoffman	8C	90RT	7	1/2"	NPT	B
114770	Radiator Trap	2 / 2nd / 211	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114775	Radiator Trap	2 / 2nd / 215	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114777	Radiator Trap	2 / 2nd / 217	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114778	Radiator Trap	2 / 2nd / 218	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114779	Radiator Trap	2 / 2nd / 219	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114797	Radiator Trap	2 / 2nd / 235	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114762	Radiator Trap	2 / 2nd / 239	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114764	Radiator Trap	2 / 2nd / 241	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114767	Radiator Trap	2 / 2nd / 245	Right Side Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114753	Radiator Trap	2 / 2nd / 249	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B

103670	Radiator Trap	2 / 2nd / 253	Back Wall Left, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103671	Radiator Trap	2 / 2nd / 253	Back Wall Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
103661	Radiator Trap	2 / 2nd / 258	Back Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
103665	Radiator Trap	2 / 2nd / 258	Right Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103674	Radiator Trap	2 / 2nd / 268	Right Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111636	Radiator Trap	2 / 2nd / 268	Under Left Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114741	Radiator Trap	2 / 2nd / 270	Under Window Middle Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114745	Radiator Trap	2 / 2nd / 274	Under Window On The Leg, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
114746	Radiator Trap	2 / 2nd / 274	Under Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111630	Radiator Trap	2 / 2nd / 257 Group Rm	Under Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111637	Radiator Trap	2 / 2nd / 269A Nurse Manager	Across From Entrance, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111638	Radiator Trap	2 / 2nd / 269A Nurse Manager	Under Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106236	Radiator Trap	2 / 3rd / 302	Below Window In The Middle, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106232	Radiator Trap	2 / 3rd / 338	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106234	Radiator Trap	2 / 3rd / 340	Across From Door, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106259	Radiator Trap	2 / 3rd / 348	Below Window On The Left, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106260	Radiator Trap	2 / 3rd / 348	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106270	Radiator Trap	2 / 3rd / 351	Below Window In The Middle, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106271	Radiator Trap	2 / 3rd / 351	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B

106268	Radiator Trap	2 / 3rd / 352	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106265	Radiator Trap	2 / 3rd / 353	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106266	Radiator Trap	2 / 3rd / 353	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106262	Radiator Trap	2 / 3rd / 355	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
106263	Radiator Trap	2 / 3rd / 355	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
106274	Radiator Trap	2 / 3rd / 357	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106258	Radiator Trap	2 / 3rd / 360	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106253	Radiator Trap	2 / 3rd / 364	Below Window To The Right Of Bed 3, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106255	Radiator Trap	2 / 3rd / 364	Below Window To The Left, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106249	Radiator Trap	2 / 3rd / 365	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106250	Radiator Trap	2 / 3rd / 365	Below Window In The Middle, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106241	Radiator Trap	2 / 3rd / 371	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106239	Radiator Trap	2 / 3rd / 372	Below Window, 0-5'	Spirax Sarco	T-125	90RT	7	1/2"	NPT	B
106264	Radiator Trap	2 / 3rd / Hallway	Below Window Outside Rm 353, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106201	Radiator Trap	2 / 4th / 404	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106202	Radiator Trap	2 / 4th / 406 Bathroom	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96464	Reheat Coil	2 / 4th / Service Rm	On Ground Straight Back By Stairs, 0-5'	Steamloc	NA	Orifice	30	3/4"	NPT	P
96469	Unit Heater	2 / 4th / Service Rm	At EF-19, 5-10'	Steamloc	NA	Orifice	30	3/4"	NPT	P

96479	Drip Leg	2 / 4th / Service Rm Stairwell Side	Backside Of AC 3, 0-5'	Steamloc	NA	Orifice	30	3/4"	NPT	P
96472	Drip Leg	2 / 5th / Service Rm	Near Roof Access, 5-10'	Hoffman	53	Float & Thermost atic	30	3/4"	NPT	B
96225	Radiator Trap	3 / 1st / 111	Right Windows, 0- 5'	CSC	NA	90RT	7	1/2"	NPT	P
96226	Radiator Trap	3 / 1st / 111	Left Window, 0-5'	CSC	NA	90RT	7	1/2"	NPT	B
96228	Radiator Trap	3 / 1st / 111B	In Corner, 0-5'	CSC	NA	90RT	7	1/2"	NPT	B
96227	Radiator Trap	3 / 1st / 112B	Under Sink, 0-5'	Hoffman	9	90RT	7	3/4"	NPT	B
96217	Radiator Trap	3 / 1st / 119A	Under Window, 0- 5'	CSC	NA	90RT	7	1/2"	NPT	P
96483	Drip Leg	3 / 1st / B28	Up On Wall, 5- 10'	Steamloc	NA	Orifice	8	3/4"	NPT	P
96235	Radiator Trap	3 / 1st / Stair 1	At Entrance, 0-5'	CSC		90RT	7	1/2"	NPT	P
96608	Radiator Trap	3 / Basement / Hallway	Stairwell 1, 5-10'	CSC	NA	90RT	15	1/2"	NPT	P
96491	Drip Leg	3 / Basement / Shipping	At Spence Valves, 5-10'	Steamloc	NA	Orifice	30	3/4"	NPT	P
96492	Drip Leg	3 / Basement / Shipping	Center Of Rm, Across From B08C, 5-10'	Steamloc	NA	Orifice	30	3/4"	NPT	P
96493	Drip Leg	3 / Basement / Shipping	Center Of Rm, Across From B08C, 5-10'	No Trap	NA	No Trap	30	3/4"	NPT	B
96500	Drip Leg	3 / Basement / Shipping B08C	Straight In From Door, Overhead, 5-10'	Steamloc	NA	Orifice	15	3/4"	NPT	P
96221	Radiator Trap	3 / Basement / Stair 4	Over Door, 5-10'	Velan	ACF	90RT	7	1/2"	NPT	B
96237	Unit Heater	3 / Ground / Connecting Tunnel To 2	At Garage Doors, 10-15'	Nicholson	FTN- 30	Float & Thermost atic	25	1"	NPT	B
96239	Drip Leg	3 / Ground / Connecting Tunnel To 4	At Stair 1 In Tunnel To 4, 5- 10'	CSC	NA	90RT	7	1/2"	NPT	B
106766	Radiator Trap	4 / 1st / 101	Behind Bed, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	P
106755	Radiator Trap	4 / 1st / 173	Below Window On The Right, 0- 5'	Mepco	1E	90RT	7	1/2"	NPT	B

106757	Radiator Trap	4 / 1st / 173	Below Window On The Right, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106409	Radiator Trap	4 / 1st / 177	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106410	Radiator Trap	4 / 1st / 177	Below Window On The Left, 0-5'	NA	NA	CAPS	7	1/2"	NPT	B
106760	Radiator Trap	4 / 1st / 184	Below Window On The Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106395	Radiator Trap	4 / 1st / Rm 170	Right Unit In Bathroom, 0-5'	Hoffman	17C	90RT	5	1/2"	NPT	P
106397	Radiator Trap	4 / 1st / Rm 172	Middle Left Unit, 0-5'	Hoffman	17C	90RT	5	1/2"	NPT	L
106398	Radiator Trap	4 / 1st / Rm 172	Middle Right Unit, 0-5'	Hoffman	17C	90RT	5	1/2"	NPT	L
106388	Radiator Trap	4 / 2nd / 164	Below Window On The Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106384	Radiator Trap	4 / 2nd / 166	Below Window On The Right, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106275	Radiator Trap	4 / 2nd / 202	Below Window, 0-5'	Hoffman		90RT	7	1/2"	NPT	B
106277	Radiator Trap	4 / 2nd / 204	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106279	Radiator Trap	4 / 2nd / 206	Below Window On The Left, 0-5'	Trane	B-1	CAPS	7	1/2"	NPT	B
106282	Radiator Trap	4 / 2nd / 208	Below Window On The Right, 0-5'	Trane	B-1	CAPS	7	1/2"	NPT	B
106283	Radiator Trap	4 / 2nd / 208	Below Window On The Left, 0-5'	Trane	B-1	CAPS	7	1/2"	NPT	B
106288	Radiator Trap	4 / 2nd / 208	Below Second Window To The Right Of Rm 236, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106301	Radiator Trap	4 / 2nd / 213	Below Window In The Middle, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B

106302	Radiator Trap	4 / 2nd / 213	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111693	Radiator Trap	4 / 2nd / 214	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111695	Radiator Trap	4 / 2nd / 214	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111697	Radiator Trap	4 / 2nd / 215	Below Window On The Left, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106308	Radiator Trap	4 / 2nd / 220	Below Window, 0-5'	Spirax Sarco	TH-125	90RT	7	1/2"	NPT	P
106311	Radiator Trap	4 / 2nd / 226	Below Window, 0-5'	Spirax Sarco	TH-125	CAPS	7	1/2"	NPT	B
106317	Radiator Trap	4 / 2nd / 234	Below Window On The Left, 0-5'	Trane	B-1	CAPS	7	1/2"	NPT	B
106297	Radiator Trap	4 / 2nd / 239	Below Window On The Left, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106298	Radiator Trap	4 / 2nd / 239	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96728	Radiator Trap	4 / 2nd / 243	Left Window, 0-5'	Trane	B-1	90RT	15	1/2"	NPT	B
96729	Radiator Trap	4 / 2nd / 243	Right Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	L
106322	Radiator Trap	4 / 2nd / 244	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106323	Radiator Trap	4 / 2nd / 246	Below Window On The Left, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106324	Radiator Trap	4 / 2nd / 246	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96708	Radiator Trap	4 / 2nd / 252	Left Side - 2nd Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96709	Radiator Trap	4 / 2nd / 252	Left Side - 4th Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	B
96710	Radiator Trap	4 / 2nd / 252	Left Side - 3rd Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P

96715	Radiator Trap	4 / 2nd / 252	Right Side - 2nd Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96716	Radiator Trap	4 / 2nd / 252	Right Side - 3rd Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96718	Radiator Trap	4 / 2nd / 252	Right Side - 5th Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	B
96723	Radiator Trap	4 / 2nd / 252	Right Side - Back Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	B
96724	Radiator Trap	4 / 2nd / 252	Left Side - Back Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96725	Radiator Trap	4 / 2nd / 252	Left Side - 6th Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
106328	Radiator Trap	4 / 2nd / 254	Below Window, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106327	Radiator Trap	4 / 2nd / 255	Below Window, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106334	Radiator Trap	4 / 2nd / 258	Below Window On The Right, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106335	Radiator Trap	4 / 2nd / 258	Below Window On The Left, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106355	Radiator Trap	4 / 2nd / 263	Below Window On The Right, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106356	Radiator Trap	4 / 2nd / 263	Below Window On The Left, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106353	Radiator Trap	4 / 2nd / 264	Below Window On The Left, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106354	Radiator Trap	4 / 2nd / 264	Below Window On The Left, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106352	Radiator Trap	4 / 2nd / 265	Below Window On The Left, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106349	Radiator Trap	4 / 2nd / 266	Below Window On The Right, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	P
106350	Radiator Trap	4 / 2nd / 266	Below Window On The Left, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	P

106347	Radiator Trap	4 / 2nd / 267	Below Window Behind The Door, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106381	Radiator Trap	4 / 2nd / 268	Below Window On The Right, 0- 5'	Mepco	1E	90RT	7	1/2"	NPT	B
96732	Radiator Trap	4 / 2nd / 269	Under Window Behind Nurses' Station, 0-5'	Mepco	1E	90RT	15	1/2"	NPT	B
106358	Radiator Trap	4 / 2nd / 271	Below Window On The Right, 0- 5'	Mepco	1E	90RT	7	1/2"	NPT	B
106362	Radiator Trap	4 / 2nd / 272	Below Window On The Left, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106364	Radiator Trap	4 / 2nd / 273	Below Window On The Left, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106372	Radiator Trap	4 / 2nd / 277	Below Window On The Right, 0- 5'	Mepco	1E	90RT	7	1/2"	NPT	B
106371	Radiator Trap	4 / 2nd / 278	Below Window On The Right, 0- 5'	Mepco	1E	90RT	7	1/2"	NPT	B
106378	Radiator Trap	4 / 2nd / 284	Below Window On The Right, 0- 5'	Mepco	1E	90RT	7	1/2"	NPT	B
106379	Radiator Trap	4 / 2nd / 284	Below Window On The Left, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106376	Radiator Trap	4 / 2nd / 285	Below Window On The Right, 0- 5'	Mepco	1E	90RT	7	1/2"	NPT	B
106280	Radiator Trap	4 / 2nd / 206A Bathroom	Below Window, 0 5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106303	Radiator Trap	4 / 2nd / 212 Bathroom	Below Window, 0 5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111692	Radiator Trap	4 / 2nd / 214 Bathroom	Below Window, 0 5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111696	Radiator Trap	4 / 2nd / 215 Bathroom	Below Window, 0 5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106331	Radiator Trap	4 / 2nd / 256 Bathroom	Below Window, 0 5'	Mepco	1E	90RT	7	1/2"	NPT	B

			Below First Window							
106287	Radiator Trap	4 / 2nd / Hallway	To The Right Of Rm 236, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
			Below Fourth Window							
106290	Radiator Trap	4 / 2nd / Hallway	To The Right Of Rm 236, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
			Below Fifth Window							
106291	Radiator Trap	4 / 2nd / Hallway	To The Right Of Rm 236, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
			Below Sixth Window							
106292	Radiator Trap	4 / 2nd / Hallway	To The Right Of Rm 236, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
			Below Second Window							
106342	Radiator Trap	4 / 2nd / Hallway	To The Left Of 260, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
			Below Third Window							
106343	Radiator Trap	4 / 2nd / Hallway	To The Left Of 260, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
			Below Window							
106369	Radiator Trap	4 / 2nd / Hallway	To The Right Of Stairway 1, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
96641	Drip Leg	4 / Basement / B05	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	L
96640	Radiator Trap	4 / Basement / B08	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96660	Radiator Trap	4 / Basement / B15	Right Radiator, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96661	Drip Leg	4 / Basement / B15	Right Radiator, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96662	Radiator Trap	4 / Basement / B15	Middle Radiator, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	L
96654	Radiator Trap	4 / Basement / B20B	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96615	Heat Exchanger	4 / Basement / B21	Under Converter, 0-5'	Spirax Sarco	FT30	Float & Thermostatic	30	1 1/2"	NPT	L
96618	Heat Exchanger	4 / Basement / B21	HW Tank, 0-5'	Nicholson	FTN-15	Float & Thermostatic	15	1 1/4"	NPT	L

96667	Radiator Trap	4 / Basement / B24	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	L
96669	Radiator Trap	4 / Basement / B24	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96670	Drip Leg	4 / Basement / B24	At Entrance, 5-10'	Hoffman	54	Float & Thermostatic	15	1"	NPT	B
96691	Drip Leg	4 / Basement / B26	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96693	Drip Leg	4 / Basement / B27	Under Window, 0-5'	Spirax Sarco	H	90RT	15	1/2"	NPT	B
96694	Radiator Trap	4 / Basement / B27	Under Window, 0-5'	Spirax Sarco	H	90RT	15	1/2"	NPT	P
96696	Radiator Trap	4 / Basement / B27A	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	L
96700	Radiator Trap	4 / Basement / B28	Under Right Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96702	Drip Leg	4 / Basement / B28	Under Window In Finishing Area, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	L
96703	Drip Leg	4 / Basement / B28C	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96704	Radiator Trap	4 / Basement / B28C	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	B
96620	Radiator Trap	4 / Basement / Computer Lab	Right Side - 1st Radiator, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96623	Radiator Trap	4 / Basement / Computer Lab	Right Side - 3rd Radiator, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	L
96720	Radiator Trap	4 / Basement / Computer Lab	Left Side - 2nd Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96735	Radiator Trap	4 / Basement / Entrance Near Bldg 82	At Door, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	B
96655	Drip Leg	4 / Basement / Greenhouse	At Entrance, 5-10'	Hoffman	NO. 8	90RT	15	1/2"	NPT	P
96658	Radiator Trap	4 / Basement / Greenhouse	At Entrance, 0-5'	Spirax Sarco	TH-125	90RT	15	1/2"	NPT	P
96652	Radiator Trap	4 / Basement / Stairwell 3	Under Window, 0-5'	Hoffman	17C	90RT	15	1/2"	NPT	P
96257	Radiator Trap	5 / 1st / 142	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
96260	Radiator Trap	5 / 1st / 144	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96264	Radiator Trap	5 / 1st / 147	Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P

96265	Radiator Trap	5 / 1st / 147	Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
96266	Radiator Trap	5 / 1st / 148	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
96255	Radiator Trap	5 / 1st / 153	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
96243	Radiator Trap	5 / 1st / 135B	Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96241	Radiator Trap	5 / 1st / 135D	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96242	Radiator Trap	5 / 1st / 135D	Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96244	Radiator Trap	5 / 1st / 135E	Behind Desk, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96240	Radiator Trap	5 / 1st / 135F	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
96738	Drip Leg	5 / Basement / B01	Left Corner Over Compressor, 5-10'	Steamloc	NA	Orifice	15	3/4"	NPT	P
96739	Drip Leg	5 / Basement / B01	Over Old Cp, 5-10'	Steamloc	NA	Orifice	15	3/4"	NPT	P
111801	Radiator Trap	6 / 1st / 100	Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111802	Radiator Trap	6 / 1st / 100	Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96299	Radiator Trap	6 / 1st / 102	Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111809	Radiator Trap	6 / 1st / 106	Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
96295	Radiator Trap	6 / 1st / 117	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
96294	Radiator Trap	6 / 1st / 122	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112410	Radiator Trap	6 / 1st / 126	Right Of Door For 126A, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111835	Radiator Trap	6 / 1st / 202	Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111836	Radiator Trap	6 / 1st / 202	Right Window, 0-5'	Hoffman	17C	90RT	7	3/4"	NPT	B
111831	Radiator Trap	6 / 1st / 208	Right Side - Bed 10, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111832	Radiator Trap	6 / 1st / 208	Right Side - Front, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111819	Radiator Trap	6 / 1st / 219	Left Side - Back, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111820	Radiator Trap	6 / 1st / 219	Left Side - Back Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L

111821	Radiator Trap	6 / 1st / 219	Right Side - Back Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111822	Radiator Trap	6 / 1st / 219	Right Side - Middle, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111823	Radiator Trap	6 / 1st / 219	Right Side - Back, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111833	Radiator Trap	6 / 1st / 221	Laundry, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
111814	Radiator Trap	6 / 1st / 108F	Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
112443	Radiator Trap	6 / 1st / 108G	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112403	Radiator Trap	6 / 1st / 119A	Below Window, 0-5'	Hoffman	NA	90RT	7	1/2"	NPT	B
112402	Humidifier	6 / 1st / 119B	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112415	Radiator Trap	6 / 1st / 119E	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112401	Radiator Trap	6 / 1st / 119F	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
96291	Radiator Trap	6 / 1st / 119G	Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
96293	Radiator Trap	6 / 1st / 119G	Left Corner, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112404	Radiator Trap	6 / 1st / 121 Lounge	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112405	Radiator Trap	6 / 1st / 132 Men's Rm	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112446	Radiator Trap	6 / 2nd / 109	Below Window On Left Across From Entrance, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111852	Radiator Trap	6 / 2nd / 200	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
112465	Radiator Trap	6 / 2nd / 202	Below Window On The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112470	Radiator Trap	6 / 2nd / 203	Below Window In The Center, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112451	Radiator Trap	6 / 2nd / 209	Below Window Left Wall From Entrance, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B

112452	Radiator Trap	6 / 2nd / 209	Below Window Left Wall From Entrance, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112458	Radiator Trap	6 / 2nd / 209	Below Window First Bed Right Wall From Entrance, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112459	Radiator Trap	6 / 2nd / 210	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111838	Radiator Trap	6 / 2nd / 220	Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111847	Radiator Trap	6 / 2nd / 228	Right Side - Back, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111848	Radiator Trap	6 / 2nd / 228	Left Side - Back, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111849	Radiator Trap	6 / 2nd / 228	Left Side - Back, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111850	Radiator Trap	6 / 2nd / 228	Left Side - Front, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111845	Radiator Trap	6 / 2nd / 229	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111843	Radiator Trap	6 / 2nd / 234	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112462	Radiator Trap	6 / 2nd / 206/Kitchen	Below Window Next To Fridge, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112481	Radiator Trap	6 / Basement / B02 Men's Locker Rm	Next To Toilet, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112482	Drip Leg	6 / Basement / B02 Men's Locker Rm	Next To Toilet, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111889	Radiator Trap	6 / Basement / B03	Inside The Door To The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111878	Drip Leg	6 / Basement / B06	Right Side - Front, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111879	Radiator Trap	6 / Basement / B06	Right Side - Front, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111880	Drip Leg	6 / Basement / B06	Right Side - Back, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111881	Radiator Trap	6 / Basement / B06	Right Side - Back, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111883	Drip Leg	6 / Basement / B06	Left Side - Back Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B

111884	Drip Leg	6 / Basement / B06	HV-6, 5-10'	Spirax Sarco	FT15	Float & Thermostatic	25	3/4"	NPT	P
111887	Radiator Trap	6 / Basement / B06	Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112491	Drip Leg	6 / Basement / B06	Across From B06C, 0-5'	Watson McDaniel	1032	Inverted Bucket	45	3/4"	NPT	P
112490	Drip Leg	6 / Basement / B06A Break Rm	Above Washer And Drier Right Of POP, 5-10'	Vent-Rite	FT341 5H	Float & Thermostatic	7	3/4"	NPT	B
111886	Drip Leg	6 / Basement / B06C	Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112495	Radiator Trap	6 / Basement / B06D	Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112480	Unit Heater	6 / Basement / B10	Across From Door Leading Outside, 5-10'	Spirax Sarco	B1H-15	Inverted Bucket	7	3/4"	NPT	P
111862	Drip Leg	6 / Basement / B12	On Left At Entrance, 5-10'	Hoffman	53	Float & Thermostatic	45	3/4"	NPT	P
112475	Drip Leg	6 / Basement / B12	Left Of HV-2, 5-10'	Inl	AN	Orifice	45	3/4"	NPT	P
111867	Drip Leg	6 / Basement / B14	Back Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112477	Drip Leg	6 / Basement / B14A	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112478	Radiator Trap	6 / Basement / B14A	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111875	Drip Leg	6 / Basement / Hallway	Outside B03, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111876	Radiator Trap	6 / Basement / Hallway	Outside B03, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111877	Radiator Trap	6 / Basement / Stair 2	At Exit, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112510	Radiator Trap	7 / 1st / 117	Below Window To The Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
112511	Radiator Trap	7 / 1st / 117	Below Window To The Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
112512	Radiator Trap	7 / 1st / 117	To The Right Of Doorway To Rm 117A, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112517	Radiator Trap	7 / 1st / 117	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112526	Radiator Trap	7 / 1st / 125	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B

112528	Radiator Trap	7 / 1st / 128	Below Window On The Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111963	Radiator Trap	7 / 1st / 130	Under Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111965	Radiator Trap	7 / 1st / 133	Back Wall, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
111966	Radiator Trap	7 / 1st / 136	Back Wall, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
112538	Radiator Trap	7 / 1st / 225	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112508	Radiator Trap	7 / 1st / 110A	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112504	Radiator Trap	7 / 1st / 110E	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112502	Radiator Trap	7 / 1st / 110F	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112503	Radiator Trap	7 / 1st / 110G	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112505	Radiator Trap	7 / 1st / 110H	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
112507	Radiator Trap	7 / 1st / 110J	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112509	Radiator Trap	7 / 1st / 110L	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111946	Radiator Trap	7 / 1st / 112A	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
111951	Radiator Trap	7 / 1st / 117A	Left Wall Front, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
111954	Radiator Trap	7 / 1st / 117A	Back Wall Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111955	Radiator Trap	7 / 1st / 117A	Right Wall Back, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
112531	Radiator Trap	7 / 1st / 131A	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112533	Radiator Trap	7 / 1st / 131C	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112535	Radiator Trap	7 / 1st / 131E	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112537	Radiator Trap	7 / 1st / 131F	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112536	Radiator Trap	7 / 1st / 131G	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112530	Radiator Trap	7 / 1st / 131L	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111968	Radiator Trap	7 / 1st / 134D	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111970	Radiator Trap	7 / 1st / 134F	Right Wall, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
111973	Radiator Trap	7 / 1st / 134I	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B

111974	Radiator Trap	7 / 1st / 134L	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
111977	Radiator Trap	7 / 1st / 135B	Right Wall, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111978	Radiator Trap	7 / 1st / 135C	Left Wall, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
111980	Radiator Trap	7 / 1st / 135D	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112529	Radiator Trap	7 / 1st / Stairwell 1	Right Of Exit Door, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111982	Radiator Trap	7 / 2nd / 200	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111986	Radiator Trap	7 / 2nd / 207	Under Right Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
111989	Radiator Trap	7 / 2nd / 208	Under Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	P
111203	Radiator Trap	7 / 2nd / 219	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
111201	Radiator Trap	7 / 2nd / 221	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112539	Radiator Trap	7 / 2nd / 225	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112543	Radiator Trap	7 / 2nd / 227	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112540	Radiator Trap	7 / 2nd / 228	Below Window On The Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
112546	Radiator Trap	7 / 2nd / 235	Below Window On The Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112548	Radiator Trap	7 / 2nd / 235	Below Window To The Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111998	Radiator Trap	7 / 2nd / 107A	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111991	Radiator Trap	7 / 2nd / 210E	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
112562	Radiator Trap	7 / 2nd / 231C	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112566	Radiator Trap	7 / 2nd / 231E	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112564	Radiator Trap	7 / 2nd / 231F	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112556	Radiator Trap	7 / 2nd / 234A	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
112554	Radiator Trap	7 / 2nd / 234C	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112551	Radiator Trap	7 / 2nd / 234E	Right Of The Door, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112549	Radiator Trap	7 / 2nd / 234F	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B

112552	Radiator Trap	7 / 2nd / 234F	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112553	Radiator Trap	7 / 2nd / 234F	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112789	Radiator Trap	7 / Basement / B01	Left Of Radiator, 0-5'	Spirax Sarco	H	CAPS	7	1/2"	NPT	P
112790	Drip Leg	7 / Basement / B01	Right Of Radiator, 0-5'	Spirax Sarco	H	CAPS	7	1/2"	NPT	B
111906	Drip Leg	7 / Basement / B02D	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111902	Drip Leg	7 / Basement / B02F	Left Wall At Radiator Control, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111915	Radiator Trap	7 / Basement / B07	Under Window, 0-5'	Spirax Sarco	H	CAPS	7	1/2"	NPT	P
111926	Radiator Trap	7 / Basement / B08C	Under Window, 0-5'	Hoffman	8C	90RT	7	3/4"	NPT	B
111927	Drip Leg	7 / Basement / B08C	Under Window, 0-5'	Hoffman	8C	90RT	7	3/4"	NPT	P
112797	Radiator Trap	7 / Basement / B08E	Below Window To The Left Of Emergency Exit, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
111919	Radiator Trap	7 / Basement / B09	Under Window, 0-5'	Spirax Sarco	H	CAPS	7	1/2"	NPT	P
111932	Radiator Trap	7 / Basement / B15A	Below Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
111933	Drip Leg	7 / Basement / B15A	Below Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111930	Drip Leg	7 / Basement / B15B	Below Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111931	Radiator Trap	7 / Basement / B15B	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111898	Radiator Trap	7 / Basement / B18C	Under Window, 0-5'	Spirax Sarco	H	CAPS	7	1/2"	NPT	P
111899	Radiator Trap	7 / Basement / B18C	Under Window, 0-5'	Spirax Sarco	H	CAPS	7	1/2"	NPT	P
111892	Unit Heater	7 / Basement / Hallway	Outside B23, 5-10'	Hoffman	FT015 H	Float & Thermostatic	7	3/4"	NPT	B
111211	Air Handling Unit	7 / PH / HV-4	Behind HV-, 0-5'	Hoffman	FT030 H	Float & Thermostatic	25	1 1/4"	NPT	B
114707	Radiator Trap	8 / 1st / 132C	Below First Window To Right Of Exit, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103601	Radiator Trap	8 / 1st / Furniture Warehouse	5th Window Across From Stair 2, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B

103603	Radiator Trap	8 / 1st / Furniture Warehouse	Second Loading Dock 2nd Window From Exit, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103604	Radiator Trap	8 / 1st / Furniture Warehouse	Second Loading Dock - Window At Exit, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103606	Radiator Trap	8 / 1st / Furniture Warehouse	Second Loading Dock - Left Side Front, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103607	Radiator Trap	8 / 1st / Furniture Warehouse	Second Loading Dock - Left Side Back, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103608	Radiator Trap	8 / 1st / Furniture Warehouse	Second Loading Dock Across From Garage Door Left, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103609	Radiator Trap	8 / 1st / Furniture Warehouse	Second Loading Dock Outside 1002 Left, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103610	Radiator Trap	8 / 1st / Furniture Warehouse	Second Loading Dock Outside 1002 Right, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103612	Radiator Trap	8 / 1st / Furniture Warehouse	Around Corner From 1077 - At Cage, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103613	Radiator Trap	8 / 1st / Furniture Warehouse	To Right Of Front Office Entrance - 2nd, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103614	Radiator Trap	8 / 1st / Furniture Warehouse	To Right Of Front Office Entrance At Cage, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103615	Radiator Trap	8 / 1st / Furniture Warehouse	Around Corner From 1077 - 2nd, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	L

103618	Radiator Trap	8 / 1st / Furniture Warehouse	In Caged Area - At Entrance, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	L
103621	Radiator Trap	8 / 1st / Furniture Warehouse	AHU-4 Side Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
103622	Radiator Trap	8 / 1st / Furniture Warehouse	AHU-4 Front Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103623	Radiator Trap	8 / 1st / Furniture Warehouse	AHU-3 Front Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	L
103624	Radiator Trap	8 / 1st / Furniture Warehouse	AHU-3 Side Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
103626	Radiator Trap	8 / 1st / Furniture Warehouse	Around The Corner From 1013 3rd Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114708	Radiator Trap	8 / 1st / Furniture Warehouse	At Loading Dock, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
114709	Radiator Trap	8 / 1st / Furniture Warehouse	3rd From Exit, 0- 5'	Hoffman	8	90RT	7	1/2"	NPT	B
114710	Radiator Trap	8 / 1st / Furniture Warehouse	Below Second Window From Corner Across From 1019, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
114714	Radiator Trap	8 / 1st / Furniture Warehouse	Buffer Closet - Side, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
114715	Radiator Trap	8 / 1st / Furniture Warehouse	1st Window Across From Stair 2, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114720	Radiator Trap	8 / 1st / Furniture Warehouse	Below Third Window Across From Stairwell 2, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114722	Radiator Trap	8 / 1st / Furniture Warehouse	Stairwell 2, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114723	Radiator Trap	8 / 1st / Furniture Warehouse	Below First Window To The Right Of Stairwell 2, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B

114728	Radiator Trap	8 / 1st / Furniture Warehouse	Radiator To The Left Behind Caged Area Across From Entrance, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114729	Radiator Trap	8 / 1st / Furniture Warehouse	Radiator To The Right Behind Caged Area Across From Entrance, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114731	Radiator Trap	8 / 1st / Furniture Warehouse	Below Second Window To The Left Of Stairwell 1, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114732	Radiator Trap	8 / 1st / Furniture Warehouse	Below First Window To The Left Of Stairwell 1, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114733	Radiator Trap	8 / 1st / Furniture Warehouse	First Window On The Left Around Corner From 1013, 0-5'	Hoffman		90RT	7	1/2"	NPT	B
114734	Radiator Trap	8 / 1st / Furniture Warehouse	Second Window On The Left Around Corner From 1013, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114718	Radiator Trap	8 / 1st / Furniture Warehouse Conference Rm	Below Window To Left, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
114719	Radiator Trap	8 / 1st / Furniture Warehouse Conference Rm	Below Window Across From Doorway, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111233	Radiator Trap	8 / 2nd / 2009	Left Window, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111231	Radiator Trap	8 / 2nd / 2015	Right Wall - 4th Radiator, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B

112584	Radiator Trap	8 / 2nd / 2018	Below Window Inside The Entering Door, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112586	Radiator Trap	8 / 2nd / 2018	Below Window In Hallway, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112587	Radiator Trap	8 / 2nd / 2018	Below Window In Hallway, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112588	Radiator Trap	8 / 2nd / 2018	Below Window In Hallway, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112589	Radiator Trap	8 / 2nd / 2018	Below Window In Hallway In Front Of Receptions Desk, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112595	Radiator Trap	8 / 2nd / 2018	Corner Office Opposite To 2009 Conference Rm, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112596	Radiator Trap	8 / 2nd / 2018	Corner Office Opposite To 2009 Conference Rm, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111234	Radiator Trap	8 / 2nd / 2036	Under Window, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111239	Radiator Trap	8 / 2nd / 2049	Below Left Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	L
111266	Radiator Trap	8 / 2nd / 2080	Behind Desk, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111269	Radiator Trap	8 / 2nd / 2087	Right Window, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111262	Radiator Trap	8 / 2nd / 2101	Right, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	P
111250	Radiator Trap	8 / 2nd / 2102	Left Wall - 1st Window, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111251	Radiator Trap	8 / 2nd / 2102	Left Wall - 2nd Window, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111253	Radiator Trap	8 / 2nd / 2102	Left Wall - 4th Window, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111257	Radiator Trap	8 / 2nd / 2102	Right Wall - 3rd Window, 0-5'	Hoffman	17C	CAPS	7	1/2"	NPT	B

111273	Radiator Trap	8 / 2nd / 2103	Right Window, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111274	Radiator Trap	8 / 2nd / 2103	Right Window, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111275	Radiator Trap	8 / 2nd / 2103	Back Wall, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
112600	Radiator Trap	8 / 2nd / 2035 Women's Bathroom	Below Window In Handicap Stall, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111276	Radiator Trap	8 / 2nd / 2103 - Rear	Left Front, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111277	Radiator Trap	8 / 2nd / 2103 - Rear	Left Back, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111280	Radiator Trap	8 / 2nd / 2103 - Rear	Back Wall Right, 0-5'	Hoffman	8	CAPS	7	1/2"	NPT	B
111287	Radiator Trap	9 / 1st / 101	Under Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111301	Radiator Trap	9 / 1st / 105	Left Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	P
111309	Radiator Trap	9 / 1st / 107	Right Wall, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111311	Radiator Trap	9 / 1st / 113	Right Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	P
111294	Radiator Trap	9 / 1st / 120	Under Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	P
111318	Radiator Trap	9 / 1st / 123	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111345	Radiator Trap	9 / 1st / 126	Left Wall Radiator 6, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111347	Radiator Trap	9 / 1st / 126	Back Wall Right, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111349	Radiator Trap	9 / 1st / 126	Right Wall Radiator 4, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	L
11132	Radiator Trap	9 / 1st / 136	Left Wall Next To Fridge, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	P
111326	Radiator Trap	9 / 1st / 136	Below Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111322	Radiator Trap	9 / 1st / 138	Under Right Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111317	Radiator Trap	9 / 1st / 140	Under Window, 0-5'	CSC		90RT	7	1/2"	NPT	P
112039	Radiator Trap	9 / 2nd / 200	Below Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112033	Radiator Trap	9 / 2nd / 204	Below Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112032	Radiator Trap	9 / 2nd / 205	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B

112023	Radiator Trap	9 / 2nd / 207	Below Window On Right, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	P
112024	Radiator Trap	9 / 2nd / 207	Below Window Across From Door, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112027	Radiator Trap	9 / 2nd / 208	Below Window, 0 5'	Hoffman	8	90RT	7	1/2"	NPT	B
112028	Radiator Trap	9 / 2nd / 209	Below Window On The Left, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112016	Radiator Trap	9 / 2nd / 211	Below Window, 0 5'	Hoffman	8	90RT	7	1/2"	NPT	P
112015	Radiator Trap	9 / 2nd / 212	Below Window, 0 5'	Hoffman	8	90RT	7	1/2"	NPT	B
112014	Radiator Trap	9 / 2nd / 214	Below Window, 0 5'	Hoffman	8C	90RT	7	1/2"	NPT	B
112001	Radiator Trap	9 / 2nd / 215	Below First Window On Left, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112002	Radiator Trap	9 / 2nd / 215	Below Second Window On Left, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112006	Radiator Trap	9 / 2nd / 215	Below Fifth Window On Left, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	P
112007	Radiator Trap	9 / 2nd / 215	Below Window Across From Entering Doorway, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112009	Radiator Trap	9 / 2nd / 215	Below Window In Last Office On The Right, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112029	Radiator Trap	9 / 2nd / 216	Below Window, 0 5'	Hoffman	8	90RT	7	1/2"	NPT	B
112063	Radiator Trap	9 / 2nd / 223	Below Left Window Across From Door, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	L
112066	Radiator Trap	9 / 2nd / 225	Below Right Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
111359	Radiator Trap	9 / 2nd / 230	Left Wall Front, 0 5'	Hoffman	8	90RT	7	1/2"	NPT	L
112050	Radiator Trap	9 / 2nd / 231	Below Left Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112049	Radiator Trap	9 / 2nd / 232	Below Window, 0 5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P

112051	Radiator Trap	9 / 2nd / 232	Below Center Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112052	Radiator Trap	9 / 2nd / 232	Below Right Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112037	Radiator Trap	9 / 2nd / 201B	Below Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112011	Radiator Trap	9 / 2nd / 215B	Below Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112042	Radiator Trap	9 / 2nd / 219B	Below Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112046	Radiator Trap	9 / 2nd / 219D	Below Left Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112053	Radiator Trap	9 / 2nd / 222 Women's Bathroom	Below Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112071	Radiator Trap	9 / 2nd / 230A	Below Right Window Across From Door, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112056	Radiator Trap	9 / 2nd / Hallway	Below Window Across From 224, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	P
112057	Radiator Trap	9 / 2nd / Hallway	Below Window Outside Rm 223, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112068	Radiator Trap	9 / 2nd / Hallway	Below Stairs Leading Out To Roof, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112019	Radiator Trap	9 / 2nd / Hallway Outside 209	Below First Window On The Right Past Rm 210, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
112020	Radiator Trap	9 / 2nd / Hallway Outside 209	Below Second Window On The Right Past Rm 210, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	L
96281	Radiator Trap	10 / 1st / 104	Right, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
96275	Radiator Trap	10 / 1st / 108	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
106940	Radiator Trap	61 / 1st / 104	Left Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106939	Radiator Trap	61 / 1st / 109	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106934	Radiator Trap	61 / 1st / 112	Left Wall Back, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112176	Radiator Trap	61 / 1st / 115	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B

112183	Radiator Trap	61 / 1st / 120	Below Third Window On Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112184	Radiator Trap	61 / 1st / 120	Below Fourth Window On Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112185	Radiator Trap	61 / 1st / 120	Below Window On Right Across From Doorway, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112186	Radiator Trap	61 / 1st / 120	Back Wall Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
112188	Radiator Trap	61 / 1st / 120	Left Wall Middle, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
112192	Radiator Trap	61 / 1st / 127	Below Second Window On Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112193	Radiator Trap	61 / 1st / 127	Below Third Window On Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112194	Radiator Trap	61 / 1st / 127	Left Of Stairway 3, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112195	Radiator Trap	61 / 1st / 127	Below Third Window On Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112196	Radiator Trap	61 / 1st / 127	Below Second Window On Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112197	Radiator Trap	61 / 1st / 127	Below First Window On Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112198	Radiator Trap	61 / 1st / 129	Below Window On Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106948	Radiator Trap	61 / 1st / 131	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106951	Radiator Trap	61 / 1st / 134	Below Window On Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106954	Radiator Trap	61 / 1st / 135	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106977	Radiator Trap	61 / 1st / 144	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106958	Radiator Trap	61 / 1st / 230	Below Middle Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106959	Radiator Trap	61 / 1st / 230	Below Window On Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B

111380	Radiator Trap	61 / 2nd / 205	Left Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
111383	Radiator Trap	61 / 2nd / 209	Left Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111393	Radiator Trap	61 / 2nd / 215	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106914	Radiator Trap	61 / 2nd / 222	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
112160	Radiator Trap	61 / 2nd / 235	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106923	Radiator Trap	61 / 2nd / 236	Under Front Right Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106924	Radiator Trap	61 / 2nd / 236	Under Back Right Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112164	Radiator Trap	61 / 2nd / 237	Below Window Across From Door, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112161	Radiator Trap	61 / 2nd / 238	Below Window On Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112162	Radiator Trap	61 / 2nd / 238	Below Window On Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106931	Radiator Trap	61 / 2nd / 242	Under Right Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112171	Radiator Trap	61 / 2nd / 244	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112169	Radiator Trap	61 / 2nd / 246	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112166	Radiator Trap	61 / 2nd / 248	Below Window On Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112167	Radiator Trap	61 / 2nd / 248	Below Window On Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111382	Radiator Trap	61 / 2nd / 205B	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
111390	Radiator Trap	61 / 2nd / 213A	Under Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112158	Radiator Trap	61 / 2nd / 234A	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106909	Drip Leg	61 / Basement / B02	Back Wall, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112112	Drip Leg	61 / Basement / B04	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112113	Radiator Trap	61 / Basement / B04	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B

112086	Drip Leg	61 / Basement / B04A	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112087	Radiator Trap	61 / Basement / B04A	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112081	Drip Leg	61 / Basement / B05A	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112073	Radiator Trap	61 / Basement / B06A	Below Window To The Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112074	Drip Leg	61 / Basement / B06B	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112075	Radiator Trap	61 / Basement / B06B	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112076	Radiator Trap	61 / Basement / B06C	Below Window, 0-5'	Spirax Sarco	T-65	90RT	7	1/2"	NPT	B
112082	Air Handling Unit	61 / Basement / B07	In The To The Left, 5-10'	Spirax Sarco	FT15	Float & Thermostatic	7	3/4"	NPT	L
112083	Radiator Trap	61 / Basement / B07	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
112084	Drip Leg	61 / Basement / B07	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112099	Radiator Trap	61 / Basement / B09A	Below Window To The Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112100	Drip Leg	61 / Basement / B09A	Below Window To The Right, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112090	Drip Leg	61 / Basement / B09E	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
112117	Radiator Trap	61 / Basement / B13	Below Window Across From B13B, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112116	Drip Leg	61 / Basement / B13 Waiting Area	Below Window Across From B13B, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112118	Drip Leg	61 / Basement / B13B	Below Window, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B

112120	Drip Leg	61 / Basement / B13C	Below Window, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
112122	Radiator Trap	61 / Basement / B13D	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112123	Radiator Trap	61 / Basement / B13D	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112130	Drip Leg	61 / Basement / B14	Below Left Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112135	Drip Leg	61 / Basement / B16	Above Condensate Tank, 5-10'	Hoffman	FT030 H-3	Float & Thermostatic	30	3/4"	NPT	B
112138	Radiator Trap	61 / Basement / B16	Below First Window On Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112141	Drip Leg	61 / Basement / B16	Below Third Window On The Left, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
112143	Drip Leg	61 / Basement / B16	In Front Of Condensate Return Tank, 5-10'	Watson McDaniel	1031	Inverted Bucket	30	3/4"	NPT	P
112152	Radiator Trap	61 / Basement / B16	Below Second Window In From The Garage Door, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
112153	Drip Leg	61 / Basement / B16	Below Second Window In From Garage Door, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106902	Drip Leg	61 / Basement / B18B	Back Wall, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	L
106904	Drip Leg	61 / Basement / B18C	Back Wall, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	P
112133	Radiator Trap	61 / Basement / B19	Below Window, 0-5'	Spirax Sarco	H	90RT	7	1/2"	NPT	B
106829	Radiator Trap	62 / 1st / 102	Left Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106830	Radiator Trap	62 / 1st / 102	Right Window, 0-5'	CSC		90RT	7	1/2"	NPT	B
114662	Radiator Trap	62 / 1st / 103	Below Window On The Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B

106848	Radiator Trap	62 / 1st / 115	Under Window, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	L
106854	Radiator Trap	62 / 1st / 119	Back Wall Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106847	Radiator Trap	62 / 1st / 122	Under Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	L
106845	Radiator Trap	62 / 1st / 123	Right Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
106846	Radiator Trap	62 / 1st / 123	Right Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B
106842	Radiator Trap	62 / 1st / 127	Under Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114665	Radiator Trap	62 / 1st / 129	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
106821	Radiator Trap	62 / 1st / 130	Bed 2, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
106823	Radiator Trap	62 / 1st / 130	Bed 5, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114652	Radiator Trap	62 / 1st / 131	Below Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106840	Radiator Trap	62 / 1st / 135	Under Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106833	Radiator Trap	62 / 1st / 136	Under Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106835	Radiator Trap	62 / 1st / 141	Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106836	Radiator Trap	62 / 1st / 141	Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
106837	Radiator Trap	62 / 1st / 141	Bathroom, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106827	Radiator Trap	62 / 1st / 147	Right Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106834	Radiator Trap	62 / 1st / 237	Under Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106849	Radiator Trap	62 / 1st / 115A	Under Window, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	L
106850	Radiator Trap	62 / 1st / 115B	Under Window, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
114703	Radiator Trap	62 / 1st / 132C	Below Second Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114704	Radiator Trap	62 / 1st / 132C	Below Third Window On The Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114669	Radiator Trap	62 / 1st / 133A	Below Window, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
106838	Radiator Trap	62 / 1st / 134B	Under Window, 0-5'	Hoffman	8	90RT	7	1/2"	NPT	B

114655	Radiator Trap	62 / 1st / 141 Wreck Rm	Below First Window On The Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114656	Radiator Trap	62 / 1st / 141 Wreck Rm	Below Second Window On The Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114657	Radiator Trap	62 / 1st / 141 Wreck Rm	Below Window On The Right Across From The Entrance, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
114658	Radiator Trap	62 / 1st / 141 Wreck Rm	Below Window Across From Entrance, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114648	Radiator Trap	62 / 1st / B30	Below Second Window On The Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	L
114664	Radiator Trap	62 / 1st / Stairwell 5	In Stairwell 5, 0- 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
114685	Radiator Trap	62 / 2nd / 203	Below Window On The Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114686	Radiator Trap	62 / 2nd / 203	Below Window On The Right, 0- 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
106878	Radiator Trap	62 / 2nd / 204	Under Window Center, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114691	Radiator Trap	62 / 2nd / 207	Below Window, 0- 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
106897	Radiator Trap	62 / 2nd / 209	Back Wall Middle, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106900	Radiator Trap	62 / 2nd / 209	Right Wall Front, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	L
106888	Radiator Trap	62 / 2nd / 214	Under Window, 0- 5'	Mepco	1E	90RT	7	1/2"	NPT	L
106892	Radiator Trap	62 / 2nd / 218	Left Window, 0-5'	Hoffman	8C	90RT	7	1/2"	NPT	B
114689	Radiator Trap	62 / 2nd / 222	Below Window, 0- 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106883	Radiator Trap	62 / 2nd / 223	Middle Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
106884	Radiator Trap	62 / 2nd / 223	Right Window, 0- 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B

106881	Radiator Trap	62 / 2nd / 224	Under Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114684	Radiator Trap	62 / 2nd / 227	Below Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
106869	Radiator Trap	62 / 2nd / 230	Bed 5, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106865	Radiator Trap	62 / 2nd / 231	Left Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	L
114674	Radiator Trap	62 / 2nd / 235	Below Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114678	Radiator Trap	62 / 2nd / 240	Below Second Window On The Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114679	Radiator Trap	62 / 2nd / 240	Below Left Window On Long Back Wall, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114680	Radiator Trap	62 / 2nd / 240	Below Middle Window On Long Back Wall, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114681	Radiator Trap	62 / 2nd / 240	Below Right Window On Long Back Wall, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114683	Radiator Trap	62 / 2nd / 240	Below First Window On The Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114688	Radiator Trap	62 / 2nd / 240	Below Window On The Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114687	Radiator Trap	62 / 2nd / 246	Below Window On Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106886	Radiator Trap	62 / 2nd / 215B	Under Window, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	B
114673	Radiator Trap	62 / 2nd / 234A	Below Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114672	Radiator Trap	62 / 2nd / 234B	Below Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
106993	Drip Leg	62 / Basement / B07	Back Wall Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	L
106994	Radiator Trap	62 / Basement / B07	Back Wall Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	L

106996	Radiator Trap	62 / Basement / B07	Back Wall Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106808	Drip Leg	62 / Basement / B10	Right Wall Back, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	L
106809	Radiator Trap	62 / Basement / B10	Right Wall Front, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106810	Drip Leg	62 / Basement / B10	Right Wall Front, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114605	Drip Leg	62 / Basement / B17	Below Window On Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
114606	Radiator Trap	62 / Basement / B17	Below Window On Right, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114609	Drip Leg	62 / Basement / B19	Below Window, 0 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
114610	Radiator Trap	62 / Basement / B19	Below Window, 0 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114613	Drip Leg	62 / Basement / B25	Below Window, 0 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
114614	Radiator Trap	62 / Basement / B25	Below Window, 0 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
114616	Drip Leg	62 / Basement / B25A	Below Window, 0 5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
106819	Drip Leg	62 / Basement / B30	Left Wall, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	L
114646	Drip Leg	62 / Basement / B30	Below Window Across From Door, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114617	Radiator Trap	62 / Basement / B33	Below First Window On Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114618	Drip Leg	62 / Basement / B33	Below First Window On Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114620	Drip Leg	62 / Basement / B33	To The Right Of The First Window On Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B

114622	Drip Leg	62 / Basement / B33	Third Radiator In On The Left, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114623	Radiator Trap	62 / Basement / B33	To The Left Of Exit B50, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114624	Drip Leg	62 / Basement / B33	To The Left Of Exit B50, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114626	Drip Leg	62 / Basement / B33	To The Right Of Exit B50, Below The Window, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114633	Radiator Trap	62 / Basement / B33	Below Second Window On Right From Entrance, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106813	Drip Leg	62 / Basement / B33A	Back Wall, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	P
106981	Radiator Trap	62 / Basement / Hallway	Outside B16A, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	L
114601	Radiator Trap	62 / Basement / Hallway	Next To Tunnel Leading Toward Bldg 61, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
114602	Radiator Trap	62 / Basement / Hallway	Next To Door To Stairway 4, 0-5'	Dunham Bush	1E	90RT	7	1/2"	NPT	B
106978	Unit Heater	62 / Basement / Tunnel	Entrance From 61, 5-10'	Armstrong	B3	Float & Thermostatic	7	3/4"	NPT	L
96360	Air Handling Unit	78 / Basement / B13C	At Fridge, Under HV-, 5-10'	Armstrong	B5	Float & Thermostatic	25	1 1/4"	NPT	B
96213	Unit Heater	78 / Basement / Canteen Loft	Center, 5-10'	Warren Webster	274	Float & Thermostatic	7	1"	NPT	P
96214	Drip Leg	78 / Basement / Canteen Loft	Top Of Stairs, 5-10'	Warren Webster	273	Float & Thermostatic	7	3/4"	NPT	P
96202	Drip Leg	78 / Basement / Theater Loft	HV-2, 5-10'	Warren Webster	273	Float & Thermostatic	7	3/4"	NPT	P

96203	Air Handling Unit	78 / Basement / Theater Loft	HV-2, 0-5'	Warren Webster	273	Float & Thermostatic	7	3/4"	NPT	P
96204	Air Handling Unit	78 / Basement / Theater Loft	HV-2, 0-5'	Armstrong	B3	Float & Thermostatic	7	3/4"	NPT	P
96208	Drip Leg	78 / Basement / Theater Loft	HV-2, 0-5'	Warren Webster	273	Float & Thermostatic	7	3/4"	NPT	P
96209	Air Handling Unit	78 / Basement / Theater Loft	HV-2, 5-10'	Dunham Bush	40-215	Float & Thermostatic	7	3/4"	NPT	P
96210	Air Handling Unit	78 / Basement / Theater Loft	HV-2, 0-5'	Warren Webster	274	Float & Thermostatic	7	1"	NPT	P
96397	Drip Leg	78 / Basement / Theater Loft	HV-1, 0-5'	Warren Webster	273	Float & Thermostatic	15	3/4"	NPT	P
96400	Drip Leg	78 / Basement / Theater Loft	HV-1, 5-10'	Warren Webster	273	Float & Thermostatic	7	3/4"	NPT	L
96392	Drip Leg	78 / Basement / Theater Service Rm	Over POP, 5-10'	Watson McDaniel	1032	Inverted Bucket	30	1/2"	NPT	P
96394	Drip Leg	78 / Basement / Theater Service Rm	Next POP Drip For Motive, 0-5'	Armstrong	B2	Float & Thermostatic	15	1/2"	NPT	B
96236	Unit Heater	78 / Ground / Connecting Tunnel To 2	At Garage Doors, 10-15'	Nicholson	FTN-30	Float & Thermostatic	7	1"	NPT	B
96684	Drip Leg	78 / Ground / Service Rm	Under Heliflow HX, 0-5'	Spirax Sarco	B1H-30	Inverted Bucket	15	1/2"	NPT	B
96686	Heat Exchanger	78 / Ground / Service Rm	Over Medical Vacuum, 5-10'	Hoffman	FT030H	Float & Thermostatic	15	3/4"	NPT	B
96370	Drip Leg	78 / PH / Service Rm	Top Of Stairs, 5-10'	Spirax Sarco	FTLC	Float & Thermostatic	7	3/4"	NPT	B
96375	Air Handling Unit	78 / PH / Service Rm	HV-1, 0-5'	Armstrong	B3	Float & Thermostatic	10	3/4"	NPT	P
96376	Drip Leg	78 / PH / Service Rm	HV-1, 0-5'	Spirax Sarco	FTLC	Float & Thermostatic	10	3/4"	NPT	P
96383	Drip Leg	78 / PH / Service Rm	Back Wall - At B&G HX, 0-5'	Watts	WFT	Float & Thermostatic	25	3/4"	NPT	B

96384	Heat Exchanger	78 / PH / Service Rm	B&G HX, 0-5'	Armstrong	A5	Float & Thermostatic	25	1 1/4"	NPT	B
111688	Radiator Trap	4 B Side / 1st / 103	Under Middle Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
111689	Radiator Trap	4 B Side / 1st / 103	Under Left Window, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	L
111683	Radiator Trap	4 B Side / 1st / 104	Under Left Window, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	P
111684	Radiator Trap	4 B Side / 1st / 104	Under Left Window, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	P
111654	Radiator Trap	4 B Side / 1st / 108	Under Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111655	Radiator Trap	4 B Side / 1st / 108	Bathroom, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	B
111656	Radiator Trap	4 B Side / 1st / 109	Bathroom, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	B
111662	Radiator Trap	4 B Side / 1st / 110	Bathroom, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111664	Radiator Trap	4 B Side / 1st / 110	Under Window In Corner, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	B
111665	Radiator Trap	4 B Side / 1st / 110	Under Window Across From Door, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	B
111659	Radiator Trap	4 B Side / 1st / 111	Under Window Next To Bathroom, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
111660	Radiator Trap	4 B Side / 1st / 111	Under Middle Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111661	Radiator Trap	4 B Side / 1st / 111	Under Window Across From Door, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111648	Radiator Trap	4 B Side / 1st / 122	Bathroom, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	L
111643	Radiator Trap	4 B Side / 1st / 123	Under Right Window, 0-5'	NA	C	CAPS	7	1/2"	NPT	B
111640	Radiator Trap	4 B Side / 1st / 130	Under Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111649	Radiator Trap	4 B Side / 1st / 131	Bathroom, 0-5'	Spirax Sarco	O	CAPS	7	1/2"	NPT	B
111703	Radiator Trap	4 B Side / 1st / 133	Under Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111674	Radiator Trap	4 B Side / 1st / 134	Under Left Window, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	B
111675	Radiator Trap	4 B Side / 1st / 135	Under Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B

111676	Radiator Trap	4 B Side / 1st / 135	Under Left Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111701	Radiator Trap	4 B Side / 1st / 136	Under Window Across From Entrance, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	L
111678	Radiator Trap	4 B Side / 1st / 137	Under Window, 0- 5'	Trane	B-1	90RT	7	1/2"	NPT	B
111721	Radiator Trap	4 B Side / 1st / 156	Bathroom, 0-5'	Mepco	1E	90RT	7	1/2"	NPT	P
111727	Radiator Trap	4 B Side / 1st / 158	Under Window, 0- 5'	Mepco	1E	90RT	7	1/2"	NPT	P
111690	Radiator Trap	4 B Side / 1st / 102 Soiled Utility	Under Window, 0- 5'	Trane	B-1	90RT	7	1/2"	NPT	P
111679	Radiator Trap	4 B Side / 1st / 105 Nurse Manager	Under Window, 0- 5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111666	Radiator Trap	4 B Side / 1st / 113 Tub/Shower Rm	Left Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111652	Radiator Trap	4 B Side / 1st / 113A Congregate Bath	Right Wall, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	P
111646	Radiator Trap	4 B Side / 1st / 114 Staff Rm	Under Window, 0- 5'	Trane	B-1	CAPS	7	1/2"	NPT	P
111706	Radiator Trap	4 B Side / 1st / 142 Speech Pathologist	Under Middle Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111709	Radiator Trap	4 B Side / 1st / 146 Therapy Program Director	Under Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111712	Radiator Trap	4 B Side / 1st / 150 PT	Under Right Window, 0-5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111711	Radiator Trap	4 B Side / 1st / 150 Recreation And Dining	Under Window, 0- 5'	Hoffman	17C	90RT	7	1/2"	NPT	B
111667	Radiator Trap	4 B Side / 1st / Hallway	Outside Rm 133, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	B
111668	Radiator Trap	4 B Side / 1st / Hallway	Outside Rm 133, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	B

111670	Radiator Trap	4 B Side / 1st / Hallway	Outside Rm 133, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	B
111671	Radiator Trap	4 B Side / 1st / Hallway	Outside Rm 133, 0-5'	Trane	B-1	90RT	7	1/2"	NPT	P