NOTES

1. REFER TO SPECIFICATION SECTION 010000 FOR REQUIREMENTS REGARDING PRE-CONSTRUCTION INVESTIGATION PRIOR TO COMMENCEMENT OF WORK. CONTRACTOR TO CONDUCT A COMPLETE SURVEY OF EVERY FIRE PROTECTION SPRINKLER HEAD TO ASSESS EACH HEAD'S AGE, CONDITION, AND VIABILITY.
2. UPON COMPLETION OF THE ABOVE SURVEY, THE VAMC COR SHALL DESIGNATE UP TO 2,400 HEADS TO BE REPLACED/REWORKED BY THE CONTRACTOR UNDER THIS CONTRACT.
3. THE 2,400 HEADS DESIGNATED BY THE VAMC COR LISTED ABOVE ARE IN ADDITION TO ANY SPECIFIC ITEMS INDICATED ON THIS SHEET.

KEYED NOTES

1. CORRECT SPRINKLER HEAD SPACING/PLACEMENT TO COMPLY WITH CODE IN ROOM 4D03. ADD AND/OR RESPACE AND RELOCATE HEADS AS REQUIRED.
2. INSTALL ADDITIONAL FIRE PROTECTION SPRINKLER HEAD(S) IN ROOM 4C22A AND MODIFY/RESPACE/RELOCATE EXISTING HEAD(S) TO MEET CODE.
3. INSTALL ADDITIONAL FIRE PROTECTION SPRINKLER HEAD(S) IN ROOM 4A13C AND MODIFY/RESPACE/RELOCATE EXISTING HEAD(S) TO MEET CODE. ADDITIONAL FIRE PROTECTION SPRINKLERS TO AREA BLOCKED OFF.
4. NO WORK REQUIRED IN ROOM 4B09.

LEGEND

AREA APPLIED TO THIS PORTION OF PROJECT



F1 FLOOR PLAN
1/16" = 1'-0"

GENERAL NOTE:
ALL EXISTING PIPING, DUCTWORK, SPRINKLERS, CONDUIT, LIGHTING OR OTHER CONSTRUCTION SHALL BE RELOCATED AS NECESSARY FOR ALL DEMOLITION AND INSTALLATION WORK.



KEY PLAN - NOT TO SCALE

FULLY SPRINKLERED
BID DOCUMENTS
FOR CONSTRUCTION

Revisions	Date

ARCHITECT/ENGINEERS:
PARADIGM
ENGINEERS AND CONSTRUCTORS
200 Envoy Circle #201, Louisville KY 40299 – PH: 502.339.8511 – www.paradigmusa.com

STATE OF KENTUCKY
BLAINE CAMIEL VAN GANSBEKE
24,788
LICENSED PROFESSIONAL ENGINEER
12 Dec 2013

Drawing Title: FIRE PROTECTION PLAN - FOURTH FLOOR BUILDING 1
Approved: Project Director:
Project Title: FIRE SAFETY UPGRADES
Location: GEORGE E WAHLEN VAMC 500 FOOTHILL DR. SALT LAKE CITY, UT
Date: 12-13-2013 | Checked: KLP | Drawn: JDM
Project Number: 259-13-C-0245
Building Number: 1
Drawing Number: 1.FX104
Office of Construction and Facilities Management
Department of Veterans Affairs

VA FORM 08-6231