

EXHIBIT F - PROPOSAL INQUIRY FORM

SOLICITATION VA244-14-R-0130

EMAIL: **Jennifer.Robinson2@va.gov**

Date of Proposal Inquiry: 3/19/2014

From: Christopher Slaglev

Company Name: Jarrett Construction Company

Address: 1661 Shug Jordan Parkway, Suite 505, Auburn, AL 36830

Phone Number: 334-386-9626

Email address: Christopher.slaglev@contractormail.net

Fax Number: 334-386-9676

Proposal Inquiry:

Ms. Robinson,

In regards to the pre-cast deck construction, some of our pre-cast manufacturers have raised questions concerning the current design of some of the structural members. In regards to standard details, means, and methods, there are a few things that they do not determine as "industry standard." With their engineered shop-drawings, are they able to construct the deck within their standard practices? Overall the function, structural integrity, and aesthetics are not be deviated from and the structure would operate and appear as designed, but slight modifications would give them the ability to engineer, fabricate and erect the deck within their standard practices. We have a couple major pre-cast subcontractors that are raising to our awareness that they cannot bid on the project with some of the details as shown on the drawings, and request clarification on this matter.

Thank you for your assistance with this request.

Response:

Pre-engineered, precast parking structure design/builder may use their standard engineered systems for this project. Precast design/builder should adhere to design intent (function, structural integrity & aesthetics) of the Bidding Documents

In addition, pre-engineered, precast parking structure design/builder shall provide a parking structure and foundations to conform with the attached VA Structural Design Manual for Parking Structures, dated October 2013.

See attached revised S000 with revised note for foundations.

Pre-engineered, precast structure shall be designed to allow for two (2) future levels.

Jonathan M. Lusin, AIA
IKM Incorporated
03.28.2014