

HVAC PIPING
GROUND FLOOR PLAN
one-eighth inch = one foot
0 5' 10' 15'


DUCTIVE ALTERNATE #1
CONTRACTOR SHALL RELOCATE EXISTING 4" STEAM AND 4" CONDENSATE RETURN LINES TO AVOID NEW FOOTINGS. CONTRACTOR TO EXCAVATE AND EXPOSE 4" STEAM AND 4" CONDENSATE LINES TO DETERMINE EXACT LOCATION AND DETERMINE IF ANY CONFLICT EXISTS WITH THE NEW FOOTINGS. HOLD PRICING FOR 60 DAYS AFTER EXPOSING THE LINES SO THAT A DETERMINATION CAN BE MADE AS TO THE NEED OF RELOCATION AND WHETHER TO ACCEPT DURING CONSTRUCTION. IF THE EXISTING LINES NEED TO BE RELOCATED.



Design Services
For The Built
Environment

GRESHAM
SMITH AND
PARTNERS

AREAS OF NEW CONSTRUCTION ARE FULLY PROTECTED
BY AN AUTOMATIC FIRE EXTINGUISHMENT SYSTEM



GROUND FLOOR PLAN
HVAC PIPING

Project Title		Date	
PHASE 3 BUILDING REPLACEMENT		MAY 14, 1999	
Building Number		Project No.	
204		621-064	
Checked		Drawing No.	
DWH		204-H16	
Drawn		Dwg. Of	
ARS			
Location		Department of Veterans Affairs	
DVAMC MOUNTAIN HOME, TN			