

## Team West Contracting

1611 Jenks Dr. Corona, CA 92880

(951)340-3426 Fax (951)340-3428

<b>R.F.I.</b> (REQUEST FOR INFORMATION)			
<b>Project #:</b>	664-12-304	<b>RFI #:</b>	4
<b>Project Name:</b>	Logistics Shelving Project	<b>Date Requested:</b>	4/11/14
<b>Solicitation No.:</b>	VA-262-14-B-0372	<b>Reference:</b>	Fire sprinkler system
<b>Drawing:</b>	N/A	<b>Specification Section:</b>	21 13 13 Wet pipe sprinkler system
<b>DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED</b>			
<p>Please be a specific as possible.</p> <p>Being that the original rfi asking about fire sprinkler system was answered with less than one week until bid is due will it be possible to extend the bid due date to be able to find a fire sprinkler sub? Also there is no drawings for this work just a spec section. Secondly regarding the fire alarm rfi that was answered saying that no fire alarm is needed. It is my understanding that when you build an enclosed space such as this one with fire sprinkler drops in them that you need fire alarm horn/strobes to meet minimum codes.</p>			
<b>OWNER RESPONSE</b>			

There is no need to push the bid deadline back as we will NOT be producing a fire sprinkler drawing. The only fire sprinkler work will be to lower the heads to the new ceiling. In my experience on both state and federal work, this can only be accomplished by a licensed fire sprinkler contractor and they would not need a spec to accomplish this (as it is dictated by code and their licensing requirements).

**OWNER TRACKING No.:**

**AMEND No.:**

**VA Project Engineer/Manager:**

**Date:**