



Hydronic Heating Ceiling Panels

- Relocate 1 unit from room 14 to new conference room.
- F&I balance of new 2 x 4 heating units in rooms 13, 13 A and 13B.
- Place heat units as shown
- Match existing units from Room 14. F&I complete heating systems. Reconnect units in Room 14. Support from slab. Provide insulation above heters.

New Concrete Pad For Multi-Speed Pump - Distributor Containing Unit

NO.	DATE	DESCRIPTION
REVISIONS		
SHEET TITLE		
Reflected Ceiling Plan & I		
PROJECT TITLE		
B6G HR OFFICES & CR		
DATE	CHECKED	DRAWN
March 7, 2014		
DRAWING NUMBER	PROJECT NUMBER	
528A5-14-511	4 of 4	
APPROVED	PROJECT NUMBER	
CHEF, ENGINEERING SERVICE	528A5-14-511	
APPROVED	DIRECTOR, V.M.C. CHANDLER	
V.A. MEDICAL CENTER		
LOCATION		
CANANDAIGUA, NY 14424		