

<b>Infection Control Construction Permit</b>					
Project Title: <b>Physical Security Def. Phase I</b>			Permit No: <b>520-14-110</b>		
Location of Construction: <b>Bldg 1, 3, 14, 15 (Non-Pharm. LAB) Areas</b>			Project Start Date:		
Project Coordinator/COTR: <b>12, 25, 26, 30, 52, 53</b>			Estimated Duration: <b>TBD</b>		
Contractor Performing Work: <b>TBD</b>			Permit Expiration Date: <b>TBD</b>		
Supervisor: <b>Brandon O'Neal</b>			Telephone:		
YES	NO	CONSTRUCTION ACTIVITY	YES	NO	INFECTION CONTROL RISK GROUP
		TYPE A: Inspection, non-invasive activity			GROUP 1: Low Risk
<b>X</b>		TYPE B: Small scale, short duration, moderate to high levels	<b>X</b>		GROUP 2: Medium Risk
		TYPE C: Activity generates moderate to high levels of dust, requires greater 1 work shift for completion			GROUP 3: Medium/High Risk
		TYPE D: Major duration and construction activities Requiring consecutive work shifts			GROUP 4: Highest Risk
CLASS I		1. Execute work by methods to minimize raising dust from construction operations. 2. Immediately replace any ceiling tile displaced for visual inspection.			
CLASS II		1. Provides active means to prevent air-borne dust from dispersing into atmosphere 2. Water mist work surfaces to control dust while cutting. 3. Seal unused doors with duct tape. 4. Block off and seal air vents. 5. Wipe surfaces with disinfectant.			
CLASS III		1. Obtain infection control permit before construction begins. 2. Isolate HVAC system in area where work is being done to prevent contamination of duct system. 3. Complete all critical barriers or implement control cube method before construction begins. 4. Maintain negative air pressure within work site utilizing HEPA equipped air filtration units. 5. Do not remove barriers from work area until complete project is thoroughly cleaned by Facilities Management Service.			
CLASS IV		1. Obtain infection control permit before construction begins. 2. Isolate HVAC system in area where work is being done to prevent contamination of duct system. 3. Complete all critical barriers or implement control cube method before construction begins. 4. Maintain negative air pressure within work site utilizing HEPA equipped air filtration units. 5. Seal holes, pipes, conduits, and punctures appropriately. 6. Construct anteroom and require all personnel to pass through this room so they can be vacuumed using a HEPA vacuum cleaner before leaving work site or they can wear cloth or paper coveralls that are removed each time they leave the work site.			
Date					
Initial					
Date					
Initial					
Construction taking place in negative pressure rooms where TB patients are housed or work with exhaust to these rooms? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes the contractor must provide written certification that all employees assigned to the work site have a negative TB screening within 90 days prior to assignment to work area.					
Additional Requirements: <b>Subject to change if Scope or Location</b>					
<b>Changes</b>					
Infection Control:			COTR:		
Safety:			Contracting Officer:		

Adapted with permission V Kennedy, B Barnard, St Luke Episcopal Hospital, Houston TX,  
 Forms modified and provided courtesy of Judene Bartley, ECSI Inc Beverly Hills MI 2002 Reviewed 2005

**For Submission purposes only**  
**Do NOT POST THIS FORM @ Job Site.**

<b>Infection Control Construction Permit</b>					
Project Title: <u>Physical Security Def. Phase II</u>				Permit No: <u>520-14-110</u>	
Location of Construction: <u>Bld 3; Pharmacy; LAB</u>				Project Start Date:	
Project Coordinator/COTR: <u>Shandon O'Neal</u>				Estimated Duration: <u>TBD</u>	
Contractor Performing Work: <u>TBD</u>				Permit Expiration Date:	
Supervisor: <u>[Signature]</u>				Telephone:	
YES	NO	CONSTRUCTION ACTIVITY	YES	NO	INFECTION CONTROL RISK GROUP
		TYPE A: Inspection, non-invasive activity			GROUP 1: Low Risk
		TYPE B: Small scale, short duration, moderate to high levels			GROUP 2: Medium Risk
<b>X</b>		TYPE C: Activity generates moderate to high levels of dust, requires greater 1 work shift for completion		<b>X</b>	GROUP 3: Medium/High Risk
		TYPE D: Major duration and construction activities Requiring consecutive work shifts			GROUP 4: Highest Risk
CLASS I		1. Execute work by methods to minimize raising dust from construction operations. 2. Immediately replace any ceiling tile displaced for visual inspection.			
CLASS II		1. Provides active means to prevent air-borne dust from dispersing into atmosphere 2. Water mist work surfaces to control dust while cutting. 3. Seal unused doors with duct tape. 4. Block off and seal air vents. 5. Wipe surfaces with disinfectant.			
CLASS III		1. Obtain infection control permit before construction begins. 2. Isolate HVAC system in area where work is being done to prevent contamination of the duct system. 3. Complete all critical barriers or implement control cube method before construction begins. 4. Maintain negative air pressure within work site utilizing HEPA equipped air filtration units. 5. Do not remove barriers from work area until complete project is thoroughly cleaned by Facilities Management Service.			
Date					
Initial					
CLASS IV		1. Obtain infection control permit before construction begins. 2. Isolate HVAC system in area where work is being done to prevent contamination of duct system. 3. Complete all critical barriers or implement control cube method before construction begins. 4. Maintain negative air pressure within work site utilizing HEPA equipped air filtration units. 5. Seal holes, pipes, conduits, and punctures appropriately. 6. Construct anteroom and require all personnel to pass through this room so they can be vacuumed using a HEPA vacuum cleaner before leaving work site or they can wear cloth or paper coveralls that are removed each time they leave the work site.			
Date					
Initial					
Construction taking place in negative pressure rooms where TB patients are housed or work with exhaust to these rooms? <u>Yes</u> <input checked="" type="checkbox"/> <u>No</u> If yes the contractor must provide written certification that all employees assigned to the work site have a negative TB screening within 90 days prior to assignment to work area.					
Additional Requirements: <u>Subject to Change if Scope or Location Changes.</u>					
Infection Control:				COTR:	
Safety:				Contracting Officer:	

Adapted with permission V Kennedy, B Barnard, St Luke Episcopal Hospital, Houston TX,  
 Forms modified and provided courtesy of Judene Bartley, ECSI Inc Beverly Hills MI 2002 Reviewed 2005

*For Submission purposes only.  
 Do NOT Post THIS FORM ON JOB SITE.*