

RFI No. 31: Amendment A00004 that was received today, Block 14, first sentence reads: "AMENDMENT A00004 IS ISSUE TO POST BLDG 128, 133, THRESHOLDS AS PROVIDED BY VA ENGINEERING." We interpreted this sentence to indicate that the thresholds were being provided by VA Engineering. After conversations on-site, we think this may not be the case. Please clarify who is to provide and install the listed thresholds.

VA Response to RFI 31:

VA is not providing the thresholds. The contractor shall field verify all thresholds and expansion joint covers and replace all exterior thresholds doors. The sliding door at the entrance approximately is missing threshold and will require a new threshold. Approximate opening of the aluminum sliding door is 5'-7" wide, the total width of the corridor is 8'-0". Provide wall expansion joint - missing from wall 8'2" high to match existing width on opposite wall. The door thresholds shall be ADA compliant.

