
















FIRE PROTECTION SYMBOLS

	FIRE LINE
	FIRE LINE TO BE DEMOLISHED
	CONCEALED SPRINKLER
	ZONE CONTROL VALVE
	TAMPER SWITCH
	FIRE DEPARTMENT HOSE VALVE
	EXISTING TO REMAIN
	RISE
	DROP
	CAP
	KEYED NOTE DESCRIBING WORK TO BE DONE
	CONNECT TO EXISTING PIPING THIS POINT
	REMOVE EXISTING PIPING TO THIS POINT

FIRE PROTECTION GENERAL NOTES

1. ALL WORK SHOWN IS NEW UNLESS INDICATED OTHERWISE.
2. COORDINATE ALL WORK WITH OTHER TRADES AND EXISTING CONDITIONS PRIOR TO THE FABRICATION OR INSTALLATION OF ANY PIPING.
3. THE DRAWINGS ARE DIAGRAMMATIC. THE CONTRACTOR MUST FIELD VERIFY ACTUAL CONDITIONS AT THE SITE PRIOR TO PROCEEDING WITH THE WORK.
4. ALL EXISTING SERVICES ARE SHOWN IN THEIR APPROXIMATE LOCATIONS.
5. ALL NEW PIPING SHALL BE INSTALLED IN SUCH A WAY THAT IT DOES NOT HAMPER ACCESS TO NEW OR EXISTING VALVES, ACCESS DOORS OR EQUIPMENT.
6. SPRINKLER PIPING SHALL BE HYDRAULICALLY DESIGNED BY THE SPRINKLER CONTRACTOR AND SHALL BE APPROVED BY ALL AUTHORITIES HAVING JURISDICTION. VELOCITIES OF WATER IN HYDRAULICALLY DESIGNED SPRINKLER PIPING SHALL NOT EXCEED TWENTY FEET PER SECOND.
7. ALL SPRINKLER HEADS INSTALLED IN LAY-IN CEILINGS SHALL HAVE THE HEADS LOCATED IN THE CENTER OF TILES. IF FOR ANY REASON HEADS CANNOT BE LOCATED IN THE CENTER OF TILES, THEN THE ARCHITECT/ENGINEER SHALL BE CONTACTED FOR NEW LOCATIONS BEFORE INSTALLING ANY HEAD OR PIPING.
8. CONTRACTOR SHALL INCLUDE IN HIS BID A WATER FLOW TEST/FIRE PUMP TEST. THE RESULTS OF WHICH SHALL BE USED TO PERFORM HYDRAULIC CALCULATIONS.
9. ENTIRE SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 13 LATEST EDITION.
10. ALL WORK SHALL BE STRICTLY COORDINATED AMONG ALL INDIVIDUAL CONTRACTORS BEFORE ANY WORK IS PERFORMED.
11. DO NOT ROUTE PIPING THROUGH ELEVATOR SHAFT(S), ELEVATOR EQUIPMENT ROOM(S) & ELECTRICAL ROOMS, PIPING TO TERMINATE AT SPRINKLER HEAD.
12. PIPES 2 1/2" & LARGER TO BE SCHEDULE 10 STEEL PIPE WITH GROOVED END PREP.
13. PIPES 2" & SMALLER TO SCHEDULE 40 STEEL PIPE WITH THREADED END PREP OR AS NEEDED.
14. PIPES TO BE SIZED PER HYDRAULIC CALCULATIONS.
15. VERIFY ALL CEILING HEIGHTS AT SITE PRIOR TO INSTALLATION. REFER TO ARCHITECTURAL DRAWINGS FOR LOCATIONS OF CEILINGS AND CEILING TYPES.
16. IN ROOMS WHICH ARE INDICATED AS BEING MECHANICAL AND ELECTRICAL ROOMS, THE SPRINKLER CONTRACTOR SHALL COORDINATE THE LOCATION OF HIS PIPING AND SPRINKLER HEADS TO AVOID INSTALLATION OVER ELECTRICAL PANELS OR EQUIPMENT. PROVIDE ADDITIONAL SPRINKLER HEADS AS NECESSARY, AT NO ADDITIONAL COST TO THE OWNER. REFER TO HVAC AND ELECTRICAL DRAWINGS.
17. DESIGN DENSITIES: A. ORDINARY GROUP 2 - 201/500 ALL AREAS.
18. FIRE PROTECTION HYDRAULIC CALCULATIONS FOR AUTOMATIC SPRINKLER SYSTEMS SHALL INCORPORATE A MINIMUM 10 PSI SAFETY FACTOR.
19. PRESSURE TEST OF THE AUTOMATIC SPRINKLER SYSTEM SHALL BE WITNESSED BY THE FIRE DEPARTMENT UNLESS SPECIFICALLY WAIVED. TWO (2) WEEKS WRITTEN ADVANCE NOTICE OF TEST SHALL BE GIVEN.
20. FIRE PROTECTION CONTRACTOR SHALL COORDINATE HIS WORK WITH MECHANICAL, ELECTRICAL AND ALL OTHER DISCIPLINES TO AVOID INTERFERENCES PRIOR TO FABRICATION OF ANY PIPE. INTERFERENCES SHALL INCLUDE ROOF OPENINGS, BUS DUCTS, GANGED CONDUIT, DUCT, RUNS, ETC.
21. ALL PIPE PENETRATIONS THROUGH FLOORS OR WALLS SHALL BE SLEEVED AND SEALED TO MAKE WATERIGHT AND MAINTAIN FIRE RATING.
22. ALL VALVE SUPERVISORY SWITCHES AND WATER FLOW SWITCHES SHALL BE PROVIDED AND INSTALLED BY THE FIRE PROTECTION CONTRACTOR AND WIRED BY THE ELECTRICAL CONTRACTOR.
23. FIRE PROTECTION CONTRACTOR SHALL BE CERTIFIED BY STATE OF PENNSYLVANIA FOR SPRINKLER SYSTEM INSTALLATION.



- 1 REMOVE EXISTING SPRINKLER HEAD.
- 2 REMOVE EXISTING SPRINKLER BRANCH PIPING.



- ① CONNECT NEW SPRINKLER BRANCH PIPING TO EXISTING PIPING IN THIS LOCATION.

2 FIRST FLOOR PLAN - FIRE PROTECTION - DEMOLITION
1/8" = 1'-0"

3 FIRST FLOOR PLAN - FIRE PROTECTION - NEW WORK
1/8" = 1'-0"

CONSULTANTS:

SEAL



AE Works Project Number: 13020

Drawing Title
SYMBOLS, NOTES, FLOOR PLANS & DETAILS

Approved: Project Director

Project Title:
ERIE VA PHARMACY IV PREP
ROOM

Location:
135 EAST 38TH STREET, ERIE, PA 16504

Date:
January 17, 2014

Checked
MEW

Drawn:
MEW

Project Number
562-13-105

Building Number

Drawing Number

F101

**Office of
Construction
and Facilities
Management**

