

# SOUTH TEXAS HEALTH CARE SYSTEM

## INFECTION CONTROL CONSTRUCTION PERMIT

AC-1-6A

PROJECT TITLE Replace HVAC Units at ALMD Phase III  
 SERVICE CHIEF Chief Leonard Daniel PHONE NUMBER (210) 617-5224  
 CONTRACT OFFICERS TECHNICAL REPRESENTATIVE George Guillen  
 PHONE NUMBER (210) 364-3724 EST. DATES OF CONSTRUCTION  
 PROJECT # 671-11-111 BUILDING # 1 FLOOR 1<sup>st</sup> Floor Interstitial  
 AFFECTED SERVICE(S) Chief Police and Offices/ Hallway and Blood Draw

*References reverse side for Definitions and IC Construction Activity Matrix Circle the appropriate class of this project.*

### SUMMARY OF RECOMMENDED PROCEDURES BASED ON CLASS

CLASS 1 _____ Date _____ Initials	1. Execute work by methods to minimize raising dust. 2. Immediately replace any ceiling tile displaced for visual inspection. 3. Minor demolition for remodeling.
CLASS 2 _____ Date _____ Initials	1. Provide active means to prevent airborne dust from dispensing into atmosphere. 2. Water mist work surfaces to control dust while cutting. 3. Seal unused doors with duct tape. 4. Block off and seal air vents. 5. Contain and transport waste in covered containers. 6. Wet mop and/or vacuum with HEPA filtered vacuum before leaving area. 7. Place dust mat at entrance and exit of work area. 8. Remove or isolate HVAC system in areas where work is being performed. 9. Post sign cautioning about spread of dust.
CLASS 3 _____ Date _____ Initials	1. Notify IC for approval before construction begins. 2. Remove or isolate HVAC system. 3. <b>Complete all barriers before construction begins. Dust barriers must be constructed of fire rated material from floor to decking at interstitial level. Dust barriers constructed at floor level must have a one hour fire rating.</b> 4. Do not remove barriers until completed project is thoroughly cleaned. 5. Vacuum work with HEPA filter vacuum as required. 6. Wet mop with disinfectant. 7. Remove barrier materials carefully to minimized spreading of dirt and debris. 8. Contain and transport waste in covered containers. 9. Post sign cautioning about spread of dust. 10. Maintain negative pressure with HEPA filtration, <b>exhaust must be routed to main ventilation or outside of building.</b>
CLASS 4 <u>5/25/12</u> Date <u>MMW</u> Initials	1-10 SAME as Class 3 11. Seal holes, pipes, conduits, and punctures appropriately. 12. Construct anteroom and require all personnel to pass through this room so they can be vacuumed using a HEPA vacuum cleaner before leaving work or their coveralls can be removed each time they leave the work site. 13. All personnel entering work site are required to wear shoe covers.

COMMENTS:

Michelle M. Whelleyham LSW IC  
 SIGNATURE OF INFECTION CONTROL REQUIRED FOR CLASS 3 & 4

5/25/12  
 DATE