

Questions Answers Nurse Call

- 1) What kind of PBY Brand and Model Number does this facility have? **See Amendment No.2, general clarification #1**
- 2) Will the Nurse Call Server be installed in an existing rack or will a new rack be required **See Amendment No.2, general clarification #2**
- 3) Will the Nurse Call Server be connected to an existing UPS or will a new UPS be required? If a new UPS is required is there a specification or preferred model **see Amendment No.2, general clarification #2.**
- 4) The Nurse Call System device connectors that are not RJ45 type are not compatible with Category 6 Enhanced Cable. It is acceptable to use standard category 6 cable for these device connections. **Fargo VAMC standards require enhanced Category 6 cabling for network connections, see Section 27 10 05 and Section 27 52 23. Follow system manufacturer requirements for other system cabling.**
- 5) Are shop drawings of the existing Hill Rom Integris P2001B Headwalls available. **Shops are not available.**
- 6) Will the owner consider a retro-fit installation of the new nurse call system as a value engineered cost saving **See Amendment No.2, general clarification #4 for phasing information.**
- 7) How is the Cisco Call Manager going to interface with the current PBX **See Amendment No.2, general clarification #3.**
- 8) How is the Cisco Call Manager going to interface with the current Nurse Call System **See Section 27 52 23, paragraph 2.18 for description of interface to new nurse call equipment.**
- 9) Has there been a site survey performed to ensure that the current wireless infrastructure can support VOIP. **Existing network is sufficient for VOIP.**