



1. COORDINATE LOCKING CONFIGURATION WITH COR PRIOR TO ORDERING SWITCHGEAR HOUSING.
2. SWITCHGEAR ENCLOSURE EXTERIOR TO BE FACTORY-PAINTED WITH ANSI 61 LIGHT GRAY POWDER-COATED PAINT.
3. LIGHTS, SWITCHES, EMERGENCY LIGHTS, RECEPTACLES, PANEL TO BE FURNISHED WITH SWITCHGEAR ENCLOSURE.
4. COORDINATE REAR-ACCESS DOOR REQUIREMENTS WITH ENCLOSURE AND SWITCHGEAR MANUFACTURERS.



1. JUNCTION BOX FOR 120 VOLT CONNECTION TO PRE-WIRED BATTERY-OPERATED EMERGENCY LIGHTING AND RECEPTACLES (PROVIDED BY ENCLOSURE MANUFACTURER). FROM JUNCTION BOX, PROVIDE 2#8, 1#10G IN 3/4" CONDUIT TO EXISTING PANEL "LLS" CIRCUIT NUMBER INDICATED.
2. NEW FIRE ALARM SYSTEM HORN/STROBE DEVICE, MINIMUM 300D. EXTEND WIRING BACK TO FACP IN EXISTING BOILER PLANT PLANT. DEVICE TO BE 100% COMPATIBLE WITH EXISTING SYSTEM. FIRE ALARM WIRING TO BE IN 1".
3. NEW PANELBOARDS BY ENCLOSURE MANUFACTURER.
4. COORDINATE LOCATION OF STATION BATTERIES WITH ENCLOSURE MANUFACTURER.

**Harrell,
Saltrick &
Hopper**

Date	10-11-2013
Project Number	613-12-111
DRAWING No.	E401

