

NOTE:
ALL NEW HEADS SHALL BE FAST ACTING, CEILING MOUNTED, RECESSED HEADS.

1 FIRE PROTECTION PLAN - NEW WORK

SCALE: 1/8" = 1' - 0"

SHEET NOTES

1. NEW SPRINKLER LAYOUT AND PIPE SCHEDULE SIZING SHALL BE IN ACCORDANCE WITH NFPA 13. ORDINARY HAZARD GROUP 2 OCCUPANCY.

SHEET KEYNOTES

1.



BUILDING C - 2ND FLOOR
KEY PLAN

FINAL SUBMITTAL
APPROVED FOR CONSTRUCTION

Revisions:	Date

CONSULTANTS:

ENGINEER-OF-RECORD STEPHEN T. STEFFE — GA. P.E. NO. 24897

ARCHITECT/ENGINEERS:

AKEA INC.
3603 NW 98th Street, Suite B
Gainesville, FL 32606
Phone: (352) 474-6124
Fax: (352) 474-6324
COA: FL #26693
AKEA Project No. 072-14

Drawing Title: FIRE SPRINKLER - NEW WORK

Approved: Project Director

Project Title: NEW SURGICAL 9TH OR SUITE

Location: Atlanta, Georgia

Date: APRIL 30, 2014 | Checked: STS | Drawn: TJM

Project Number: 508-14-105

Building Number:

Drawing Number: FP200

36 of 36

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231