

AIR DEVICE SCHEDULE (SUPPLY)																
MARK	TYPE	AIR FLOW				MAX APD		MOUNTING	PANEL/FRAME SIZE		NECK SIZE		NC	DAMPER	FINISH	REMARKS
		MIN		MAX					IN x IN	[mm x mm]	IN	[mm]				
		CFM	[L/s]	CFM	[L/s]	IN WG	[Pa]									
CD-1	TITUS TDV	135	[64]	200	[94]	0.067	[17]	LAY-IN	24X24	[610X610]	8	[203]	20			----
CD-2	TITUS TDV	201	[95]	305	[140]	0.063	[16]	LAY-IN	24X24	[610X610]	10	[254]	20			----
CD-3	TITUS TDV	306	[140]	405	[190]	0.060	[15]	LAY-IN	24X24	[610X610]	12	[305]	20			----
CD-4	TITUS TDV	406	[190]	595	[280]	0.059	[15]	LAY-IN	24X24	[610X610]	14	[356]	20			----
CD-5	TITUS TDV	140	[66]	200	[94]	0.067	[17]	SURFACE	-	-	8	[203]	20			----
CD-6	TITUS TDV	201	[95]	305	[140]	0.063	[16]	SURFACE	-	-	10	[254]	20			----
CD-7	TITUS TDV	306	[140]	405	[190]	0.060	[15]	SURFACE	-	-	12	[305]	20			----
CD-8	TITUS TDC	0	[0]	120	[57]	0.143	[36]	LAY-IN	24X24	[610X610]	6	[152]	22			----
CD-9	TITUS TDC	121	[57]	225	[110]	0.123	[31]	LAY-IN	24X24	[610X610]	8	[203]	22			----
CD-10	TITUS TDC	226	[110]	340	[160]	0.100	[25]	LAY-IN	24X24	[610X610]	10	[254]	22			----
CD-11	TITUS TDC	341	[160]	470	[220]	0.085	[21]	LAY-IN	24X24	[610X610]	12	[305]	22			----
CD-12	TITUS TDC	0	[0]	120	[57]	0.143	[36]	SURFACE	-	-	6	[152]	22			----
SG-1	TITUS 300RL	100	[47]	235	[110]	0.066	[17]	WALL	8X8	[203X203]	8X8	[203X203]	20			----
<div>NOTES</div> <div>1. SEE FLOOR PLAN FOR THROW PATTERN.</div> <div>2. SEE DETAIL FOR DAMPER IN BRANCH DUCT SERVING EACH DIFFUSER.</div> <div>3. PROVIDE SQUARE TO ROUND ADAPTER.</div>																