

Principals:
Archie D. Fellenzer Jr., P.E.
Mark D. Fellenzer, P.E.
John D. Fellenzer, P.E.
Eric D. Fellenzer, P.E.

May 30, 2014

Stratton VA Medical Center, Albany, NY
Renovate Front Lobby and VA Police Suite
VA Project No. 528A8-13-801

Attn: Tom Lucas, COR

Re: Response to RFI #2 – HVAC Specification Section 23 3100 Ducts and Casings Part 2.2, C.1
FE Project No. 12-278

Please see below for our response to your question regarding the above referenced specification section.

Section 23 3100 - Specification HVAC Ducts and Casings Part 2.2, C.1

Question: Specification Section 23 3100 HVAC Ducts and Casings Part 2.2, C.1 states that
"Rectangular Duct: Galvanized Steel, minimum 1.0mm (20 Gage).
Is this the intent? All air handling units are 1 inch external static.

Response: **Attached please find revised Specification Section 23 3100, Sub-section 2.2, B is revised.
Item C, Seal Class stays, item 1 Rectangular Duct: is deleted.**