

three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one quarter inch = one foot
one eighth inch = one foot

NOTES
1. REFER TO SPECIFICATION SECTION 010000 FOR REQUIREMENTS REGARDING PRE-CONSTRUCTION INVESTIGATION PRIOR TO COMMENCEMENT OF WORK.

KEYED NOTES
1 CORRECT GYPSUM BOARD WALL DEFICIENCIES TO ACHIEVE A SMOKE BARRIER RATING OF THE EXISTING WALL IN ROOM 1A19B TO MEET NFPA101-18.3.6.2.3 "TO FORM A BARRIER TO LIMIT THE TRANSFER OF SMOKE." IN ADDITION, CORRECT AND FIRESTOP ALL PENETRATIONS TO MEET THESE CODE REQUIREMENTS. THE VA ARCHITECTURAL DESIGN MANUAL SECTION 4.24.5 ALLOWS "FOR SMOKE BARRIERS, EXTEND ONE LAYER OF GYPSUM BOARD FROM FLOOR TO UNDERSIDE OF STRUCTURE ABOVE ON PARTITIONS, AND FIRESTOP JUNCTURE OF GYPSUM BOARD AND ADJOINING MATERIAL TO PREVENT THE PASSAGE OF SMOKE." REFER TO PHOTO A6/1.AE601.

LEGEND
AREA APPLIED TO THIS PORTION OF PROJECT

