


three inches = one foot
 one and one half inches = one foot
 one inch = one foot
 three quarters inch = one foot
 one half inch = one foot
 three eighths inch = one foot
 one quarter inch = one foot
 one eighth inch = one foot

NOTES
 1. REFER TO SPECIFICATION SECTION 010000 FOR REQUIREMENTS REGARDING PRE-CONSTRUCTION INVESTIGATION PRIOR TO COMMENCEMENT OF WORK.

KEYED NOTES
 ① CORRECT GYPSUM BOARD WALL DEFICIENCIES TO ACHIEVE A SMOKE BARRIER RATING OF THE EXISTING WALL IN ROOM GA09 TO MEET NFPA101-18.3.6.2.3 "TO FORM A BARRIER TO LIMIT THE TRANSFER OF SMOKE." IN ADDITION, CORRECT AND FIRESTOP ALL PENETRATIONS TO MEET THESE CODE REQUIREMENTS. THE VA ARCHITECTURAL DESIGN MANUAL SECTION 4.24.5 ALLOWS "FOR SMOKE BARRIERS, EXTEND ONE LAYER OF GYPSUM BOARD FROM FLOOR TO UNDERSIDE OF STRUCTURE ABOVE ON PARTITIONS, AND FIRESTOP JUNCTURE OF GYPSUM BOARD AND ADJOINING MATERIAL TO PREVENT THE PASSAGE OF SMOKE."
 ② CORRECT GYPSUM BOARD WALL DEFICIENCIES TO ACHIEVE A SMOKE BARRIER RATING OF THE EXISTING WALL IN ROOM GA04 TO MEET NFPA101-18.3.6.2.3 "TO FORM A BARRIER TO LIMIT THE TRANSFER OF SMOKE." IN ADDITION, CORRECT AND FIRESTOP ALL PENETRATIONS TO MEET THESE CODE REQUIREMENTS. THE VA ARCHITECTURAL DESIGN MANUAL SECTION 4.24.5 ALLOWS "FOR SMOKE BARRIERS, EXTEND ONE LAYER OF GYPSUM BOARD FROM FLOOR TO UNDERSIDE OF STRUCTURE ABOVE ON PARTITIONS, AND FIRESTOP JUNCTURE OF GYPSUM BOARD AND ADJOINING MATERIAL TO PREVENT THE PASSAGE OF SMOKE."

LEGEND
 [Shaded Box] AREA APPLIED TO THIS PORTION OF PROJECT

F1 PARTIAL FLOOR PLAN
 1/16" = 1'-0"



FULLY SPRINKLERED
 BID DOCUMENTS
 FOR CONSTRUCTION

AMENDMENT #3 5/20/14 AMENDMENT #1 5/01/14 Revisions:		ARCHITECT/ENGINEERS: <div style="text-align: center;"> PARADIGM ENGINEERS AND CONSTRUCTORS <small>200 Envoy Circle #201, Louisville KY 40299 - PH: 502.339.8511 - www.paradigmusa.com</small> </div>		Drawing Title: FIRE BARRIER PLAN - GROUND FLOOR BUILDING 1 EAST		Project Title: FIRE SAFETY UPGRADES		Project Number: 660-14-104 Building Number: 1		Office of Construction and Facilities Management 	
				Approved Project Director:		Location: GEORGE E WAHLEN VAMC 800 FOOHILL DR. SALT LAKE CITY, UT		Drawing Number: 1.AE100		Date: 12-19-2013 Checked: KLP Drawn: JDM	