

F1 PARTIAL FLOOR PLAN
1/16" = 1'-0"

NOTES

1. REFER TO SPECIFICATION SECTION 010000 FOR REQUIREMENTS REGARDING PRE-CONSTRUCTION INVESTIGATION PRIOR TO COMMENCEMENT OF WORK. CONTRACTOR TO CONDUCT A COMPLETE SURVEY OF EVERY FIRE PROTECTION SPRINKLER HEAD TO ASSESS EACH HEAD'S CONDITION AND VIABILITY.
2. UPON COMPLETION OF THE ABOVE SURVEY, THE VAMC COR SHALL DESIGNATE UP TO 2,400 HEADS TO BE REPLACED/REWORKED BY THE CONTRACTOR UNDER THIS CONTRACT.
3. THE 2,400 HEADS DESIGNATED BY THE VAMC COR LISTED ABOVE ARE IN ADDITION TO ANY SPECIFIC ITEMS INDICATED ON THIS SHEET.

KEYED NOTES

1. INSTALL A SPRINKLER HEAD IN ROOM 1D04A PER CODE NFPA13 AS ONE DOES NOT EXIST. REFER TO PHOTO A2/1.FX601.
2. REWORK EXISTING FIRE SPRINKLER HEAD AND PIPING PER CODE IN ROOM 1A19B. REFER TO PHOTO A4/1.FX601.

LEGEND

AREA APPLIED TO THIS PORTION OF PROJECT



N

KEY PLAN - NOT TO SCALE

GENERAL NOTE:
ALL EXISTING PIPING, DUCTWORK, SPRINKLERS, CONDUIT, LIGHTING OR OTHER CONSTRUCTION SHALL BE RELOCATED AS NECESSARY FOR ALL DEMOLITION AND INSTALLATION WORK.

FULLY SPRINKLERED
BID DOCUMENTS
FOR CONSTRUCTION

Revisions:	Date
AMENDMENT #3	5/20/14

ARCHITECT/ENGINEERS:

PARADIGM
ENGINEERS AND CONSTRUCTORS
200 Envoy Circle #201, Louisville KY 40299 – PH: 502.339.8511 – www.paradigmusa.com

Drawing Title: FIRE PROTECTION PLAN - FIRST FLOOR BUILDING 1 WEST

Approved: Project Director

Project Title: FIRE SAFETY UPGRADES

Location: GEORGE E WAHLEN VAMC
500 FOOTHILL DR SALT LAKE CITY, UT

Date: 12-13-2013 | Checked: KLP | Drawn: JDM

Project Number: 660-14-104

Building Number: 1

Drawing Number: 1.FX101A

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231