



1. PROVIDE DEVICES WITH PROJECT. PROVIDE ALTERNATE CREDIT FOR PROVIDING OCCUPANCY SENSORS IN EXISTING SPACES NOT HAVING OTHER WORK DONE.

1. EXISTING SPACES WITH NO OTHER LIGHTING WORK TO GET WALL MOUNTED OCCUPANCY SENSORS. UNLESS OTHERWISE NOTED.
2. FIXTURES TO MATCH EXISTING.
3. FIXTURES SHALL BE TYPE A UNLESS OTHERWISE NOTED.
4. CONNECT TO EXISTING 277V LIGHTING CIRCUIT. PROVIDE CORRIDOR OCCUPANCY SENSORS WHERE NONE EXIST. SPACING TO COMPLY WITH MANUFACTURERS RECOMMENDATIONS.
5. CONNECT EXISTING LIGHTING FIXTURES TO LIFE SAFETY EGRESS CIRCUIT.

1. TYPE A FIXTURE IS TYPICAL UNLESS OTHERWISE NOTED.
2. TYPE X FIXTURE IS TYPICAL EXIT SIGN U ON.
PROVIDE DIRECTIONAL ARROWS AS INDICATED ON DRAWINGS



FOR BIDDING PURPOSES ONLY
FINAL SUBMISSION
FULLY SPRINKLERED

		CONSULTANTS:				ARCHITECT/ENGINEERS:		Drawing Title		Project Title		Project Number			
								ELECTRICAL NEW WORK AREA D LIGHTING		BALTIMORE VA MEDICAL CENTER MANAGED CARE / ED IMPROVEMENTS AND ENROLLMENT CENTER		512-511			
						CULPEPER VETERANS ASSOCIATES, LLC 4116 WALNEY ROAD, SUITE A CHANTILLY, VA 20151 (703) 955-7160 FAX (703) 890-3031		Scale 1/8"=1'-0"		Location BALTIMORE, MARYLAND		Building Number 1			
PRELIMINARY		08/22/11						Approved: Project Director		Date 8/17/2012		Checked SN			Drawing Number EL103
Revisions:		Date										Dwg. 134 of 175		VA Department of Veterans Affairs	