

# Meeti

Project: RENOVATE 6 EAST

Facilitator

Meeting

Company Name:

Place/R

Q1 Name of person asking question:

The plans show grouted frames but the frames on the 5th floor weren't grouted. Do we need to grout them?

A1

Grouted door frames are expected inside patient bath rooms

Q2

Name of person asking question:

The plans say that stair #11 will be extended to the 6th floor and a door installed by the VA. Will this work be complete before we start so that we can use that stairway?

A2

The stairs will not be extended as part of this project and should not be considered for use

Q3

Name of person asking question:

Is there a preference on location of a staging area?

A3

Staging areas external to the medical center and outside of the construction area must be requested by the contractor. The Cor will request approval of external spaces through the medical center Please note that contractors are not allowed to park on station.

Q4

Name of person asking question:

Is there a preference for where the dumpster is located and which window we take out and put back?

A4

Dumpster locations are requested from the COR and approved through the medical center

Q5

Name of person asking question:

Can we use the freight elevators for bringing material inside.

A5

Yes the freight elevators are the only elevators used to take material to and from the

Q6

Name of person asking question:

Question:

A6

Q7

Name of person asking question:

Question:

