

ADDENDUM NO. 1

CLARIFICATIONS - SPECIFICATIONS

1. SPECIFICATION SECTION 23 09 23 - DIRECT-DIGITAL CONTROL SYSTEM FOR HVAC
 - A. Direct-Digital Control System shall apply to all new HVAC equipment that is to be controlled by the DDC system such Air Handling Unit 1-AC-27, Return Fan 1-RAF-27, existing Hot Water Radiant Panel valves, Airflow Measuring Stations, Constant/Variable Volume Boxes and Exhaust Tracking Boxes. Also, all equipment shall be removed from the existing network 800 and tied into the new DDC panel. No HVAC equipment is to remain on the existing network panel.

CLARIFICATIONS - DRAWINGS

1. DRAWING NO. MH-AC27-701
 - A. All new and existing HVAC equipment is to be converted to the Niagara DDC system. No HVAC equipment is to remain on the existing network panel.
2. DRAWING NO. MH-AC27-702
 - A. All new and existing HVAC equipment is to be converted to the Niagara DDC system. No HVAC equipment is to remain on the existing network panel.

Bidder shall give due consideration to the content of this Addendum in the preparation of his Proposal and shall so indicate in his Proposal in space provided herein.

Failure of a bidder to acknowledge receipt of this Addendum on his Proposal may be sufficient cause for rejection of the Bid.

H.F. LENZ COMPANY
Consulting Engineers
1407 Scalp Avenue
Johnstown, PA 15904