

PB13C

Monday, June 30, 2014
10:10 AM

12-Mar-12			PANEL: PB13C				LOCATION: ELECT CLOSET D3449					
#	DESCRIPTION	LOAD	BKR	CIR	A	B	C	CIR	BKR	LOAD	DESCRIPTION	#
R	D3427, D3429	360	20	1	900			2	20	540	D3439	R
R	D3428	900	20	3		1440		4	20	540	D3439	R
R	D3426	1080	20	5			1620	6	20	540	D3439	R
	SPARE		20	7	0			8	20		SPARE	
	SPARE		20	9		0		10	20		SPARE	
	SPARE		20	11			0	12	20		SPARE	
	SPARE		20	13	0			14	20		SPARE	
	SPARE		20	15		0		16	20		SPARE	
	SPARE		20	17			0	18	20		SPARE	
	SPARE		20	19	0			20	20		SPARE	
	SPARE		20	21		0		22	20		SPARE	
	SPARE		20	23			0	24	20		SPARE	
	SPARE			25	0			26			SPARE	
	SPARE			27		0		28			SPARE	
	SPARE			29			0	30			SPARE	
	SPARE			31	0			32			SPARE	
	SPARE			33		0		34			SPARE	
	SPARE			35			0	36			SPARE	
	SPARE			37	0			38			SPARE	
	SPARE			39		0		40			SPARE	
	SPARE			41			0	42			SPARE	
					900	1440	1620					
SIZE:		225	GROUND:					STANDARD		NOTES:		
VOLTAGE:		208	MOUNTING:					SURFACE		POWER LOADS ONLY		
PHASE:		3	ENCLOSURE:					NEMA 1		NORMAL POWER		
WIRE:		4	# OF 1-POLE CIRCUITS					42				
LUGS:		MLO	CONNECTED KVA:							4.0		
BREAKER AIC RATING:		10K	CONNECTED AMPS:							11.0		
BUS:		COPPER	NET KVA:							4.0		
NEUTRAL:		100%	NET AMPS:							11.0		