

U.S. DEPARTMENT OF VETERANS AFFAIRS

REQUEST FOR INFORMATION

SOLICITATION NO. VA245-14-B-0083

MANAGED CARE/EMERGENCY DEPT/ENROLLMENT CENTER

PROJECT NO. 512-511

Date Submitted: 6/20/14 RFI # 69

Reference/Subject: Recpt. 66" A.F.F. + J-Box

Spec. Section No. / Title \_\_\_\_\_

Page / Art. / Para. \_\_\_\_\_

Drawing No.: EP-103

Plan/Detail/Schedule: \_\_\_\_\_

Request (Explain your request in detail here): There are receptacles shown 66"  
A.F.F. + J-Box. Is there a specific type of junction box to be  
provided with this assembly?

Submitted by (Company Name): TUCKMAN - BARBEE (Person Name): Michelle Clements  
CONSTRUCTION CO., INC.

VAMHCS Response: Outlets installed at this height are typically for above-countertop, so please check for GFCI outlet  
requirement. Other than that, no special requirements.

Date Received by VAMHCS: \_\_\_\_\_

Response by: \_\_\_\_\_ Date: \_\_\_\_\_

Attachments: \_\_\_\_\_

A/E Firm Response: \_\_\_\_\_

A/E Firm Response Date: \_\_\_\_\_

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL,  
NOCHELLE.ELLIOTT@VA.GOV OR BY FAX TO 410-642-1102  
PLEASE NOTE DEADLINE FOR RECEIPT OF ALL QUESTIONS IS JUNE 6, 2013 BY 12:00 NOON EST.