

REQUEST FOR INFORMATION (RFI)
VA-251-14-B-0054

PROJECT NUMBER:	553-303a	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Expand Emergency Center		
PROJECT LOCATION:	Department of Veterans Affairs VA Medical Center 4646 John R. Street Detroit, MI 48201		
SUBMITTED BY:	Tooles Contracting Group	City/State:	Detroit, MI
PHONE NO.:	313-221-8500		

TO:

Aleda E. Lutz VAMC
Department of Veterans Affairs
Attn: Contracting Office, 90CSC
1500 Weiss Street
Saginaw, MI 48602

RFI NO.: 003	DATE: 8-5-14	SPEC/DWG. REFERENCE: 101419 Dimensional Letter Signage
REPLY NEEDED BY: ASAP		

INFORMATION NEEDED:

1. The specification calls for translucent face channel letters. Halo letters are reverse channel with light coming from the back of the letter not the front. Are we to provide channel letters or reverse channel letters? Please clarify.

REPLY:

Article 2.2.A.1 (Section 10 14 19) calls for "backlighting character construction".



Digitally signed by Warren J. Brown
DN: c=US, cn=Warren J. Brown, o=VAMC
Detroit, ou=Facility Engineering
Date: 2014.08.06 14:56:50 -04'00'

REPLY FROM: Thomas McKercher, AIA, C2AE	DATE: August 6, 2014
ATTACHMENTS:	COPY TO: