

REQUEST FOR INFORMATION (RFI)
VA-251-14-B-0054


| | | |
|-------------------|---|---|
| PROJECT NUMBER: | 553-303a | Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner. |
| PROJECT TITLE: | Expand Emergency Center | |
| PROJECT LOCATION: | Department of Veterans Affairs VA Medical Center 4646 John R. Street Detroit, MI 48201 | |

| | | | |
|---------------|-----|-------------|--|
| SUBMITTED BY: | DBC | City/State: | |
| PHONE NO.: | | | |

TO:

Aleda E. Lutz VAMC
Department of Veterans Affairs
Attn: Contracting Office, 90CSC
1500 Weiss Street
Saginaw, MI 48602

| | | |
|------------------|-----------------|----------------------|
| RFI NO.: | DATE: 8/7/14 | SPEC/DWG. REFERENCE: |
| REPLY NEEDED BY: | | |

| | |
|--|--|
| INFORMATION NEEDED: SPEC DO NOT IDENTIFY ANY TESTING OF THE OUGRCURRENT DEVICES. IS THIS REQUIRED? | |
| REPLY: Contractor shall provide certification that all materials have been properly installed, connected, and tested. This includes circuit breakers. | |
| <div style="text-align: center;"><div>Digitally signed by Warren J. Brown DN: c=US, cn=Warren J. Brown, o=VAMC Detroit, ou=Facility Engineering Date: 2014.08.13 12:54:41 -04'00'</div></div> | |

| | |
|-----------------------|-----------------|
| REPLY FROM: | DATE: |
| Scott Floyd, PE, C2AE | August 13, 2014 |
| ATTACHMENTS: | COPY TO: |