

LEGEND:


- NEW SPRINKLER
- ⊗ EXISTING SPRINKLER - TO REMAIN
- NEW SPRINKLER PIPE
- - - - EXISTING SPRINKLER PIPE - TO REMAIN

GENERAL NOTES:

1. CONTRACTOR SHALL PROVIDE ALL MATERIALS AND LABOR FOR THE REMOVAL, REPLACEMENT AND INSTALLATION OF THE PARTIAL FIRE SPRINKLER SYSTEM IN ACCORDANCE WITH NFPA 13-2010 AND DESIGN SPECIFICATIONS.
2. CONTRACTOR SHALL COORDINATE THE LOCATION OF ALL NEW SPRINKLER PIPING/HEADS WITH LOCATION OF NEW HVAC EQUIPMENT/ACCESS DOOR AND PIPING.
3. ALL PIPE, FITTINGS, AND DEVICES SHALL BE SECURELY SUPPORTED TO THE BUILDING STRUCTURE OR FLOOR IN ACCORDANCE WITH NFPA 13-2010.
4. SPRINKLER HANGERS TO BE INSTALLED AND SPACED PER NFPA 13-2010 TABLE 9.2.2.1(A).
5. CONTRACTOR SHALL FIELD VERIFY ALL INFORMATION CONTAINED ON THE DESIGN DRAWINGS AND IS RESPONSIBLE FOR THE INSTALLATION OF THE SYSTEM IN ACCORDANCE WITH NFPA 13-2010 AND THE DESIGN SPECIFICATIONS.



REVISIONS	DESCRIPTION	DATE



ENGINEER:
RMD CONSULTING, LLC
2815 VALLEY VIEW LANE, STE. 214
DALLAS, TX 75234
P: 972-488-8077 F: 972-488-8174
OK REG. ENGINEERING FIRM: 5183

CONSULTANTS:
ARCHITECT:
ARCHITECTURAL CONCEPTS, INC.
669 AIRPORT FREEWAY, STE. 300
HURST, TX 76053
P: 817-285-8885 F: 817-285-8021

APPROVED:	APPROVED: Interior Designer	APPROVED: Safety Manager	APPROVED: Medical Center Director
APPROVED:	APPROVED:	APPROVED: Infection Control Nurse	APPROVED: Associate Director
APPROVED:	APPROVED:	APPROVED: Industrial Hygienist	APPROVED: Chief of Staff
APPROVED:	APPROVED:	APPROVED: President A.F.G.E. 2250	APPROVED: Chief of Engineering Service

DRAWING TITLE
LEVEL 3 WING C:
INTERSTITIAL SPRINKLER
DEMOLITION PLAN

PROJECT NO. 623-11-107
CONTRACT NO. VA256-12-C-0295

BUILDING NO. CLINICAL
AUTOCAD FILE NAME:

PROJECT TITLE
REPLACE LABORATORY
AIR HANDLING UNITS

DESIGNED BY: MRG
DRAWN BY: MRG
CHECKED BY: TEI

LOCATION
Jack C. Montgomery VA Medical Center

DATE 08/19/13
SCALE AS SHOWN
DRAWING NO. SDA1.0
DWG. 38 OF 40

DEPARTMENT OF
VETERANS AFFAIRS