



KEYED NOTES:

- 1 FIELD VERIFY LOCATION OF DPT-1 WITH CONTROL CONTRACTOR. RELOCATE/REINSTALL AS REQ'D BY INSTALLATION OF NEW AHU-10.
- 2 CWM-5: ONCON MODEL "F-1200" DUAL TURBINE FLOW METER. COORDINATE LOCATION WITH CONTROL CONTRACTOR. INSTALL IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.


ASBESTOS NOTE:  
IF THE EXECUTION OF THIS WORK REQUIRES THE DISTURBING OF ANY SUBSTANCE WHICH APPEARS TO BE ASBESTOS OR WHICH MAY CONTAIN ASBESTOS FIBER, NOTIFY THE OWNER BEFORE CONTINUING WORK AT THE SUSPECT LOCATION. ANY MATERIAL TESTING POSITIVE SHALL BE REMOVED BY THE OWNER BEFORE WORK CONTINUES.

NOTE: EXISTING CONDITIONS SHOWN WERE DERIVED FROM OWNER FURNISHED DRAWINGS AND FIELD OBSERVATIONS. SOME BUILDING FEATURES AND MEP SYSTEMS ARE NOT SHOWN FOR CLARITY. FIELD VERIFY BUILDING CONSTRUCTION. FIELD VERIFY THE LOCATION, SIZE AND QUANTITY OF ALL EQUIPMENT.

NOTE: REFER TO DETAILS AND SCHEMATICS FOR PIPING, VALVES, FITTINGS AND OTHER APPURTENANCES REQUIRED, BUT NOT SHOWN FOR CLARITY.



REVISIONS	DESCRIPTION	DATE



Dept. of Veterans Affairs  
Jack C. Montgomery  
Medical Center  
1011 Honor Height Drive  
Muskogee, Oklahoma 74401

ENGINEER:  
RMD CONSULTING, LLC  
2815 VALLEY VIEW LANE, STE. 214  
DALLAS, TX 75234  
P: 972-488-8077 F: 972-488-8174  
OK REG. ENGINEERING FIRM: 5183

CONSULTANTS:  
ARCHITECT:  
ARCHITECTURAL CONCEPTS, INC.  
669 AIRPORT FREEWAY, STE. 300  
HURST, TX 76053  
P: 817-285-8885 F: 817-285-8021

APPROVED: \_\_\_\_\_  
APPROVED: \_\_\_\_\_  
APPROVED: \_\_\_\_\_  
APPROVED: \_\_\_\_\_

APPROVED: Interior Designer  
APPROVED: \_\_\_\_\_  
APPROVED: \_\_\_\_\_  
APPROVED: \_\_\_\_\_

APPROVED: Safety Manager  
APPROVED: Infection Control Nurse  
APPROVED: Industrial Hygienist  
APPROVED: President A.F.G.E. 2250

APPROVED: Medical Center Director  
APPROVED: Associate Director  
APPROVED: Chief of Staff  
APPROVED: Chief of Engineering Service

DRAWING TITLE  
HVAC CW PIPING  
SCHEMATIC  
PROJECT NO.  
623-11-107  
AUTOCAD FILE NAME:  
CLINICAL

PROJECT TITLE  
REPLACE LABORATORY  
AIR HANDLING UNITS  
DESIGNED BY:  
DRAWN BY:  
CHECKED BY:  
LOCATION  
Jack C. Montgomery VA Medical Center

DATE  
8/19/2013  
SCALE  
AS SHOWN  
DRAWING NO.  
MH5.0  
DWG. 22 OF 40

DEPARTMENT OF  
VETERANS AFFAIRS