

*QUESTIONS AND ANSWERS for Solicitation Notice-VA256-14-Q-1349*

**1. Q-What is the fire pump engine make and size**

- a. It's a John Deere. Filters are OEM, John Deere. Part numbers are on the filters. All filters etc. are to be OEM. No aftermarket products.

**2. Q-Will our technicians be required to have any particular safety training or site specific training?**

- a. No, need to have experience with this type of work and use practical safe working skills.

**3. Q-Will our technicians be required to get any work permits (electrical, LOTO, etc.) from facilities maintenance prior to commencing work?**

- a. No, However pre-schedule and check in upon arrival is required and an electrical VA personnel will accompany contractor staff on all PM's on each visit.

**4. Q-We need to know the specification for the fuel testing of what they are looking for in the fuel?**

- a. Fuel testing will need to look for water content or anything unusual