

VA Iowa City 60201421

Ellerbe Becket/

AECOM

Response to Bidder Questions 2014.08.15

636-14-2-4111-0009 | Construction | Relocate Surgical Operating Rooms | VAMC Iowa City

1. Discrepancies in Room Number references on Interior elevation sheets AS802 thru 804.

Response: The room numbers are incorrect, however the elevation as referenced on the enlarged plans are correct. Delete references to Room numbers on Elevation titles.

2. Material discrepancy on Detail 8/AS912

Response: Revise note indicating "Quartz" to read "Solid Surface Material".